

**From:** "Kozyra, Jan" <jan.kozyra@pgnmail.com>  
**To:** "Richard Emch" <RLE@NRC.gov>  
**Date:** 4/3/03 3:06PM  
**Subject:** Radiant Energy Shield SAMA

It turns out that your suggestion about the radiant energy shield for the DS cable was a good one.

We have done a quick evaluation and found that the avoided risk benefit for such a mod would be \$152,371, based on a CDF reduction from 7.04 E-06/yr to zero. We believe that adding radiant energy shielding for potentially affected portions of the conduit could be accomplished for less than \$50,000, specifics not yet determined.

We are continuing to take a last look for any additional fire SAMAs. We haven't found anything yet, but will inform you of the results.

**CC:** "RLP3@NRC.gov" <RLP3@NRC.gov>

**ML031070463**