



Entergy Nuclear Operations, Inc  
Pilgrim Nuclear Power Station  
600 Rocky Hill Road  
Plymouth, MA 02360

Mike Bellamy  
Site Vice President

April 16, 2003

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555-0001

SUBJECT: Entergy Nuclear Operations, Inc.  
Pilgrim Nuclear Power Station  
Docket No. 50-293  
License No. DPR-35

Supplement to Request for Amendment to Technical Specifications  
Associated With the Refueling Interlocks, Specifications 3/4.10.A and D

- REFERENCES:
1. Entergy letter, Request for Amendment to Technical Specifications Associated With the Refueling Interlocks, Specifications 3/4.10.A and D, dated August 18, 2002
  2. Entergy letter, Supplement to Request for Amendment to Technical Specifications Associated With the Refueling Interlocks, Specifications 3/4.10.A and D, dated March 26, 2003

LETTER NUMBER: 2.03.047

Dear Sir or Madam:


By the References 1 and 2 Entergy Nuclear Operations, Inc. (Entergy) proposed to amend the Pilgrim Station Operating License, DPR-35. Discussions with the NRC staff have identified additional information was necessary to facilitate review and approval of the requested changes.

The attached supplementary information does not impact Entergy's conclusion in Reference 1 that the proposed amendment does not involve a significant hazards consideration.

Please contact Mr. Bryan Ford, Licensing Manager, at (508) 830-8403, if you have any questions or require additional information.

I declare under penalty of perjury that the foregoing is true and correct. Executed on this 16th day of April 2003.

Sincerely,

A handwritten signature in black ink, appearing to read "R. Bellamy", followed by the printed name "FOR R. BELLAMY".

Robert M. Bellamy

203047

A001

Entergy Nuclear Operations, Inc.  
Pilgrim Nuclear Power Station

Letter Number: 2.03.047  
Page 2

Attachment: 1. Supplemental Information - 1 page

cc: Mr. Travis Tate, Project Manager  
Office of Nuclear Reactor Regulation  
Mail Stop: 0-8B-1  
U.S. Nuclear Regulatory Commission  
1 White Flint North  
11555 Rockville Pike  
Rockville, MD 20852

U.S. Nuclear Regulatory Commission  
Region 1  
475 Allendale Road  
King of Prussia, PA 19406

Senior Resident Inspector  
Pilgrim Nuclear Power Station

Mr. Steve McGrail, Director  
Mass. Emergency Management Agency  
400 Worcester Road  
Framingham, MA 01702

Mr. Robert Walker  
Radiation Control Program  
Executive Offices of Health and Human Services  
174 Portland Street, 5<sup>th</sup> Floor  
Boston, MA 02114

## **ATTACHMENT 1**

### **Supplemental Information**

## **Supplemental Information**

In a conference call on April 16, 2003 it was identified that the following information was needed to complete the review of the requested changes.

1. Currently, when maintenance is performed which could impact the operability of the refueling interlocks, the appropriate parts of the Technical Specification surveillance procedure (Pilgrim procedure 8.10.1) is performed prior to declaring the equipment operable. This practice of using the Technical Specification surveillance procedure to verify operability following maintenance that may have affected the ability of the equipment to perform its Technical Specification function is not being changed by the implementation of the proposed Technical Specification requirements.
2. The reactor mode switch discussed in Specification 3.10.A is monitored by the plant staff in several ways. First, when the source range monitors (SRMs) or intermediate range monitors (IRMs) are required to be operable the position of the reactor mode switch is monitored and recorded once per shift. Also, the reactor mode switch position is checked and documented as part of the control room shift turnover. In addition to these checks, inappropriate switch movement during a refueling outage would be annunciated to the control room staff by RPS actuations if the reactor mode switch was moved to the RUN or SHUTDOWN positions.
3. As discussed in the Technical Specification Bases, all control rods must be fully inserted when fuel is being loaded into the reactor core.