

Dominion Nuclear Connecticut, Inc.  
Millstone Power Station  
Rope Ferry Road  
Waterford, CT 06385



**Dominion™**

APR 17 2003

Docket No. 50-336  
B18881

RE: 10 CFR 50.90

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

**Millstone Power Station, Unit No. 2**  
**Request for Additional Information: Licensing Basis**  
**Document Change Request 2-12-02, Unit No. 2 Technical**  
**Specification Change – Operation With Main Steam Line**  
**Code Safety Valves Inoperable (TAC NO. MB5799)**

In a letter dated August 1, 2002<sup>(1)</sup>, Dominion Nuclear Connecticut, Inc. (DNC) proposed changes to the Millstone Unit No. 2 Technical Specifications relating to the Main Steam Line Code Safety Valves technical specifications. On September 19, 2002<sup>(2)</sup>, a request for additional information (RAI) was received from the NRC. On October 18, 2002<sup>(3)</sup>, DNC provided a response to the September 19, 2002 RAI. During a conference call on April 2, 2003, the NRC indicated that a clarification is required for the response to Question (3) included in our submittal dated October 18, 2002.

The purpose of this submittal is to clarify the response to Question 3 of the October 18, 2002 submittal.

The original response to Question 3 states in part:

"Based on the above results it has been concluded that plant operation in accordance with the proposed Technical Specification Table 3.7.1 power levels will assure that pressure relief capacities are sufficient to limit the primary and

- 
- (1) J. A. Price letter to U.S. NRC, "Millstone Power Station, Unit No. 2, Licensing Basis Document Change Request 2-12-02, Unit No. 2 Technical Specification Change – Operation With Main Steam Line Code Safety Valves Inoperable," dated August 1, 2002.
- (2) Facsimile from R. Ennis, U.S. NRC to R. Joshi, DNC, Inc., "Issues for Discussion in Upcoming Telephone Conference Regarding Proposed Amendment to Technical Specifications, Operation with Main Steam Line Code Safety Valves Inoperable," dated September 19, 2002.
- (3) J. A. Price letter to U.S. NRC, "Millstone Power Station, Unit No. 2, Request for Additional Information: Licensing Basis Document Change Request 2-12-02, Unit No. 2 Technical Specification Change Operation with Main Steam Line Code Safety Valves Inoperable," dated October 18, 2002.

A001

secondary system pressures to less than 110% of their design limits of 2750 and 1100 psia respectively."

The revised response is as follows:

"Based on the above results it has been concluded that plant operation in accordance with the proposed Technical Specification Table 3.7.1 power levels will assure that pressure relief capacities are sufficient to limit the primary system pressures to less than 110% of the plant design limit (Design Limit is 2500 psia) and the secondary system pressure to less than 110% of the Chapter 14 analyses limit of 1000 psia. It should be noted that the Chapter 14 analyses limit is more conservative than the secondary plant component and piping design limit of 1000 psig."


The clarification provided above will not affect the conclusions of the Safety Summary and Significant Hazards Consideration discussion provided in the DNC August 1, 2002 submittal.

There are no regulatory commitments contained within this letter.

If you should have any questions on the above, please contact Mr. Ravi Joshi at (860) 440-2080.

Very truly yours,


DOMINION NUCLEAR CONNECTICUT, INC.



  
\_\_\_\_\_  
J. Alan Price  
Site Vice President - Millstone

Subscribed and sworn to before me

this 17<sup>th</sup> day of April, 2003.

  
\_\_\_\_\_  
Notary Public

My Commission Expires: 2/28/2003

cc: See next page

**Lorrie A. Arzamarski**  
**Notary Public**  
**Commission Expires**  
**February 28, 2006**

U.S. Nuclear Regulatory Commission  
B18881/Page 3

cc: H. J. Miller, Region 1 Administrator  
R. B. Ennis, NRC Senior Project Manager, Millstone Unit No. 2  
Millstone Senior Resident Inspector

Director  
Bureau of Air Management  
Department of Environmental Protection  
79 Elm Street  
Hartford, CT 06106-5127