

Friday, April 25, 2003

Document Update Notification

COPYHOLDER NO: TRM-U2-102

TO: GSB-NRC

ADDRESS: OS-DOCUMENT CONTROL,
WASHINGTON, D.C. 20555

DOCUMENT NO: TRM-U2


TITLE: TECHNICAL REQUIREMENTS MANUAL
(UNIT 2)

CHANGE NO: 013

ADDITIONAL INFO:



← If this box is checked, please sign, date, and return within 5 days.



ANO-1 Docket 50-313



ANO-2 Docket 50-368

Signature

Date

SIGNATURE CONFIRMS UPDATE HAS BEEN MADE

RETURN TO:

ATTN: DOCUMENT CONTROL-(N-GSB-67)
ARKANSAS NUCLEAR ONE
1448 SR 333
RUSSELLVILLE, AR 72801

2001

TECHNICAL REQUIREMENTS MANUAL REVISION 13

ARKANSAS NUCLEAR ONE, UNIT NO. 2

Replace the following pages of the associated Technical Requirements Manual with the attached pages.

REMOVE PAGES

INSERT PAGES

Index Pages

na

-----na

Technical Requirements Pages

3.6-1

-----3.6-1

CONTAINMENT SYSTEMS

CONTAINMENT RECIRCULATION SYSTEM

LIMITING CONDITION FOR OPERATION

3.6.4.3 At least two independent containment recirculation fans shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTION:

With one of the above required containment recirculation fans inoperable, restore the inoperable fan to OPERABLE status within 30 days. If not restored within 30 days or with no containment recirculation fan OPERABLE, initiate a condition report to document the condition and determine any limitations for continued operation of the plant.

SURVEILLANCE REQUIREMENTS

4.6.4.3 Each of the above containment recirculation fans shall be demonstrated OPERABLE:

- a. At least once per 92 days on a STAGGERED TEST BASIS BY:
 1. Verifying that the fan can be started on operator action in the control room, and
 2. Verifying that the fan operates for at least 15 minutes.
- b. At least once per 18 months by verifying a flow rate of at least 4500 cfm per fan.