

1315

STARTED 1C AFW PP FOR PMT ON MV-08-3 AND FOR CODE RUN FOR TROUBLESHOOTING ALERT VIBRATION BY SYSTEM PERFORMANCE AND PREDICTIVE MAINTENANCE.

1350 - TRIPPED 1C AFW PP. PMT ON MV-08-3 WAS SATISFACTORY, HOWEVER INBOARD PUMP VIBRATION REMAINS IN THE ALERT RANGE.

1355 - MV-08-3 HAS BEEN RESET AND 1C AFW PP IS AVAILABLE FOR START, BUT IS STILL OOS PENDING C.R. DISPOSITION.

1600 - DECLARED AFW PUMP 1C BIS, ALL PMTs SAT AND ENGINEERING DETERMINED VALVE WAS NOT DAMAGED BY THE REPETITIVE CYCLES THIS MORNING (CR 01-0143 REFERS).

1501

MADE 10CFR 50.72 NOTIFICATION REGARDING RECOVERY OF INJURED GREEN TURTLE AND SUBSEQUANT NOTIFICATION OF AN OUTSIDE GOVERNMENT AGENCY (THE FLORIDA WILDLIFE CONSERVATION COMMISSION).

2100

DECLARED 1C CHARGING PP OOS ON ECO FOR ACCUMULATOR PM OLRM COMPLETED SAT.

0420 1/26/01

STARTED 1C CHARGING PP IN PREP FOR RETURN TO SERVICE TESTING; SECURED 1A CHARGING PP.

0428: SECURED 1C CHARGING PP AND STARTED 1A CHARGING PP. 1C CHARGING PP CODE RUN COMPLETED SAT PER DATA SHEET 14.

0430: DECLARED 1C CHARGING PP BIS.

*** OPERATIONS ***

OPERATING LOG HIGHLIGHTS: (cont'd)

Unit 2

Time

Log Entry

0800 1/25

OPENED TCB #1 AND 5 FOR ELECTRICAL MAINT TO SWAP OUT TCB #1.

0806 - ELECTRICAL MAINT COMPLETED TESTING TCB #1, CLOSED TCB# 1 AND 5 (SAT).

B/5