

---

**Operations Department Chronological Log Unit 2**

---

Mar-02

NUMBER:	6260	NUC POWER:	100
DATE:	3/9/2001	DELTA T POWER:	100
SHIFT:	DAY	MWE:	910
BOARD RCO:	de la Guardia	CEA GROUP #:	5
DESK RCO:	PRICE	POSITION:	133
NWE:	BASHWINER	T AVG:	575
ANPS:	Soule	BORON:	934
NPS:	PARKS	Xe WORTH:	-2463
		MODE:	1
		CALCULATED SD MARGIN:	>3600

**MAJOR MILESTONES OR ACTIVITIES TO BE PERFORMED DURING THE SHIFT:**

2.2 GALS. OF ACID/11.2 GALS. OF WATER. BR=5.03 TO 1.

**TIME LOG ENTRIES**

6:30 ASSUMED SHIFT

7:40 SGBDTF ROLLUP DOOR OPEN FOR MAINTENANCE, SGBDTF VENTILATION SYSTEM OOS.

10:09 PORV 1474 PLACED IN OVERRIDE FOR CALIBRATION OF TI-1115

11:15 PORV 1474 PLACED IN NORMAL, CALIBRATION COMPLETE AND SAT

2:45 2 TURTLES REPORTED REMOVED FROM UNIT#2, TURTLE PERSON NOTIFIED

3:30 TURTLE PERSON NOTIFIED US HE WILL BE RELEASING BOTH TURTLES IN APPROX 1 HOUR, NEITHER TURTLE WAS INJURED OR IN NEED OF REHABILITATION

4:30 TIME ENTERED IN ERROR

6:30 LIA-9005 BIS

7:15 RECEIVED E-26 (CONDENSER WATER BOX VACUUM LOW) ALARM INTERMITTANTLY, DISPATCHED NPO, DISCOVERED 2A2 VACUUM TANK CAUSING ALARM

**TIME REVIEWER'S COMMENTS**

B/h