

2100 COMMENCED UNIT DOWNPOWER IAW NOP-1-0030125

2228 SECURED THE 1B MFW PP.

2255 B CONDENSATE PUMP SECURED

2323 SWAPPING STATION ELECTRICS TO STARTUP TRANSFORMERS.

2324 - COMPLETED WAPPING STATION ELECTRICS TO STARTUP TRANSFORMERS.

0000 MANUALLY TRIPPED REACTOR AND TURBINE - ENTERED 1-EOP-01, SPTA'S. NPO PERFORMING APPENDIX X

0007 - COMPLETED SPTAS, ALL SAFETY FUNCTIONS MET AT THIS TIME, GOING TO EOP-2.

0017 - COMPLETED EOP-2, ALL SAFETY FUNCTIONS SATISFIED. RE-ENTERING TURBINE SHUTDOWN PROCEDURE.

0014 NPO REPORTS COMPLETED APPENDIX X WITH EXCEPTION OF VERIFYING TURBINE ON TURNING GEAR - TURBINE SPEED CURRENTLY 600 RPM AND BEARING OIL LIFT PP IS OPERATING.

0025 STARTED 1A & 1B AFW PPS TO MAINTAIN STEAM GENERATOR LEVELS. SWAPPED FROM MAIN FEED TO AUX FEED.

0030 COMMENCED DEPRESSURIZATION TO 1750 PSIA IAW COOLDOWN PROCEDURE.

0042 NWE REPORTS APPROXIMATELY 2 GPM OIL LEAK BETWEEN BOTH OF THE LP TURBINES.

0058 - CLOSED MSIVs AND BROKE CONDENSER VACUUM TO MINIMIZE LP TURBINE SEAL LEAK.

0210 - NICK WHITING HAS BEEN CONTACTED CONCERNING THE OIL SPILL ASSOCIATED WITH THE TURBINE LUBE OIL LEAK. THE LEAK IS CONTAINED AND THE REQUIRMENTS OF AP 0010502 ARE MET.

0235 - COMMENCED VENTING H2 FROM THE MAIN GENERATOR DUE TO OIL LEAK.

PLACED ATMOSPHERIC DUMP VALVES IN SERVICE AND SECURED FROM SBCS OPERATION.

0045

*** OPERATIONS ***

OPERATING LOG HIGHLIGHTS: (cont'd)

Unit 2 Time	Log Entry
1008 3/30	NRC NOTIFIED OF DEAD GREEN SEA TURTLE FOUND IN INTAKE NETS

B/8