

LAR Number	Unit	Submittal Date	Exp Issue Date	Description	Next Action
P95-05B	2	11/17/99	TBD	EDG: RISK-BASED AOT EXTENSION TO 14 DAYS FOR ONE EDG: ENG-FIRE RISK ANALYSIS FOR PSL-2	NRC
G95-06	1.2	3/20/00	TBD	ENDANGER SPECIES ACT SECTION 7 CONSULTATION ON SEA TURTLE ENTRAPMENT IN THE PSL INTAKE CANAL	NRC
P2000-07	1.2	7/26/00	4/1/01	TECHNICAL SPECIFICATION BASES CONTROL PROGRAM	NRC
G2000-06	1	10/4/00	TBD	EXEMPTION FROM 10 CFR 50 APPENDIX R 2.g.2 K-1 CABLE SEPARATION EXEMPTION INSIDE CONTAINMENT	NRC
P2000-08	1.2	11/27/00	3/31/01	DELETE REQUIREMENT FOR PASS	NRC
G2000-04	2	11/27/00	11/1/01	EXEMPTION FROM 10 CFR 50.55a(f)(4)(ii) TO ALIGN THE U1 AND U2 PROGRAMS TO SAME UPDATE SCHEDULE BASED ON U1 SCHEDULE	NRC
P2000-21	2	11/28/00	5/15/01	UNREVIEWED SAFETY QUESTION REVISED POST-TRIP STEAM LINE BREAK ANALYSIS	NRC
P2000-04	1	12/4/00	5/1/01	MSLB CREDITING NON-SAFETY MAIN FW & CONDENSATE PUMP TRIPS	NRC
P2000-02A	1	1/17/01	4/15/01	24-HR EDG RUN WITH UNIT ON-LINE FOR SHUTDOWN SL1-17	NRC

*** LICENSING ***
(cont'd)

LICENSEE EVENT REPORT STATUS:

UNIT 1:

NONE

UNIT 2:

LER Number	Rev	Due Date	Description	CR Number
2001-001	0	5/13/01	Unit 2 Reactor Trip	01-0516

*** PROTECTION SERVICES ***

NAME: R. Walker

DATE/TIME: 04/03/2001

EMERG ASSESS/OFFSITE RESP/COMM CAPABILITIES:

SITE

ERDADS:	OK
Emergency Response Facilities (ERFS):	OK
Emergency Communication Equipment:	OK
Prompt Notification System incl. Sirens:	OK

B/11