

WEEKLY BRANCH CHIEF REPORT

BRANCH: 3

SIGNATURE: S. Ninh

WEEK ENDING: 02/08/02

SIGNIFICANT PLANT ISSUES/EVENTS

Crystal River - n/a.

St. Lucie - On 02/05/02, Unit 2 was shutdown to Mode 3 for planned maintenance outage to fix a hot spot on the 2A main generator output transformer high voltage 240 kv bus and to repair 2A MG set trip breaker problem. The unit returned to full power on 02/06/02.

On 02/06/01, a 50.72 report was submitted involving a rescued sea turtle from the plant intake canal (EN 38634).

Turkey Point - On 02/05/02, Regional Administrator visited the Turkey Point, toured the plant with resident inspectors, and met the Site VP.

SIGNIFICANT INSPECTION FINDINGS/BRANCH ACCOMPLISHMENTS

Completed the security advisory audit at St. Lucie this week.

Conducted the E.O.C meeting for branch 3 plants in Region II office this week.

Worked on the E.O.C. assessment letters and local officials invitation letters.

STAFFING ASSIGNMENTS/AVAILABILITY

Ms. Laramine Bliven, St. Lucie Secretary has submitted her resignation this week. She plans to work for a couple more weeks, until 2/18/02. This information has been forwarded to Region II Personnel.

S. Rudisail will conduct the security advisory audit at the Crystal River from 02/11-13/02.

S.. Ninh is acting Branch Chief through February 23, 2002.

PLANNED ACTIVITIES NEXT WEEK

Routine resident inspection activities.

B/41