

Dominion Nuclear Connecticut, Inc.  
Millstone Power Station  
Rope Ferry Road  
Waterford, CT 06385



**Dominion™**

MAY 7 2003

Docket Nos. 50-336  
50-423  
B18895

RE: 10 CFR 50.71(a)

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Millstone Power Station, Unit Nos. 2 and 3  
Facility Operating License Nos. DPR-65 and NPF-49  
Monthly Operating Reports

In accordance with the reporting requirements of Technical Specification 6.9.1.7 for Millstone Unit No. 2, and Technical Specification 6.9.1.5 for Millstone Unit No. 3, enclosed are the Monthly Operating Reports for the month of April 2003. Attachment 1 contains the Millstone Unit No. 2 Monthly Operating Report and Attachment 2 contains the Millstone Unit No. 3 Monthly Operating Report.

There are no regulatory commitments contained within this submittal.

If you should have any questions regarding this submittal, please contact Mr. David W. Dodson at (860) 447-1791, extension 2346.

Very truly yours,

DOMINION NUCLEAR CONNECTICUT, INC.

---

Stephen P. Sarver, Director  
Nuclear Station Operations and Maintenance

Attachments (2)

cc: H. J. Miller, Region I Administrator  
R. B. Ennis, NRC Senior Project Manager, Millstone Unit No. 2  
V. Nerses, NRC Senior Project Manager, Millstone Unit No. 3  
Millstone Senior Resident Inspector

IE24

Docket Nos. 50-336  
50-423  
B18895

Attachment 1

Millstone Power Station, Unit No. 2

Facility Operating License No. DPR-65  
Monthly Operating Report  
April 2003

**OPERATING DATA REPORT**

DOCKET NO.	<u>50-336</u>
UNIT NAME	<u>Millstone 2</u>
DATE	<u>05/01/2003</u>
COMPLETED BY	<u>S. Stark</u>
TELEPHONE	<u>(860) 447-1791</u>
EXTENSION	<u>4419</u>

OPERATING STATUS			
1.	Unit Name:	Millstone Unit No. 2	
2.	Reporting Period:	April 2003	
3.	Licensed Thermal Power (MWt):	2700.0	
4.	Design Electrical Rating (Net MWe):	870.0	
5.	Maximum Dependable Capacity (Net MWe):	871.5	
6.	If Changes Occur in Capacity Ratings (Items Number 3 through 5) Since Last Report, Give Reasons:	Not Applicable	
		This Month	Year-to-Date
7.	Number of Hours Reactor Was Critical:	719.0	2430.2
8.	Hours Generator On-Line:	719.0	2415.0
9.	Unit Reserve Shutdown Hours:	0.0	0.0
10.	Net Electrical Energy Generated (MWH):	631582.1	2109958.4

**OPERATING SUMMARY:**

The unit operated at or near 100% power for the month of April with the exception of a planned downpower to 98% power on April 3, 2003, for circulating water system maintenance. The plant was returned to full power on April 8, 2003.

# UNIT SHUTDOWNS

DOCKET NO. 50-336  
UNIT NAME Millstone 2  
DATE 05/01/2003  
COMPLETED BY S. Stark  
TELEPHONE (860) 447-1791  
EXTENSION 4419

REPORTING MONTH: April 2003

NO.	DATE	TYPE <sup>1</sup>	DURATION (HOURS)	REASON <sup>2</sup>	METHOD OF SHUTTING DOWN REACTOR <sup>3</sup>	CAUSE / CORRECTIVE ACTIONS COMMENTS
						There were no unit shutdowns in April 2003.
<sup>1</sup> F: Forced S: Scheduled		<sup>2</sup> Reason: A - Equipment Failure (Explain) B - Maintenance or Test C - Refueling D - Regulatory Restriction E - Operator Training / License Examination F - Administrative G - Operational Error (Explain) H - Other (Explain)			<sup>3</sup> Method: 1 - Manual 2 - Manual Trip 3 - Automatic Trip 4 - Continued from previous month 5 - Other (Explain)	

Docket Nos. 50-336

50-423

B18895

Attachment 2

Millstone Power Station, Unit No. 3

Facility Operating License No. NPF-49

Monthly Operating Report

April 2003

## OPERATING DATA REPORT

DOCKET NO. 50-423  
UNIT NAME Millstone 3  
DATE 05/01/2003  
COMPLETED BY K. Cook  
TELEPHONE (860) 447-1791  
EXTENSION 6572

OPERATING STATUS			
1.	Unit Name:	Millstone Unit No. 3	
2.	Reporting Period:	April 2003	
3.	Licensed Thermal Power (MWt):	3411.0	
4.	Design Electrical Rating (Net MWe):	1153.6	
5.	Maximum Dependable Capacity (Net MWe):	1130.5	
6.	If Changes Occur in Capacity Ratings (Items Number 3 through 5) Since Last Report, Give Reasons:	Not Applicable	
		This Month	Year-to-Date
7.	Number of Hours Reactor Was Critical:	719.0	2879.0
8.	Hours Generator On-Line:	719.0	2848.6
9.	Unit Reserve Shutdown Hours:	0.0	0.0
10.	Net Electrical Energy Generated (MWH):	830314.1	3261530.0
			Cumulative
			105223.7
			103494.1
			0.0
			113103035.1

### OPERATING SUMMARY

The unit operated at 100% power throughout the month of April 2003.

# UNIT SHUTDOWNS

DOCKET NO. 50-423  
UNIT NAME Millstone 3  
DATE 05/01/03  
COMPLETED BY K. Cook  
TELEPHONE (860) 447-1791  
EXTENSION 6572

REPORTING MONTH: April 2003

NO.	DATE	TYPE <sup>1</sup>	DURATION (HOURS)	REASON <sup>2</sup>	METHOD OF SHUTTING DOWN REACTOR <sup>3</sup>	CAUSE / CORRECTIVE ACTIONS COMMENTS
						There were no unit shutdowns in April 2003.
<sup>1</sup> F: Forced S: Scheduled		<sup>2</sup> Reason: A - Equipment Failure (Explain) B - Maintenance or Test C - Refueling D - Regulatory Restriction E - Operator Training / License Examination F - Administrative G - Operational Error (Explain) H - Other (Explain)			<sup>3</sup> Method: 1 - Manual 2 - Manual Trip 3 - Automatic Trip 4 - Continued from previous month 5 - Other (Explain)	