

ATTACHMENT TO LICENSE AMENDMENT NO. 331  
RENEWED FACILITY OPERATING LICENSE NO. DPR-38  
DOCKET NO. 50-269  
AND  
TO LICENSE AMENDMENT NO. 331  
RENEWED FACILITY OPERATING LICENSE NO. DPR-47  
DOCKET NO. 50-270  
AND  
TO LICENSE AMENDMENT NO. 332  
RENEWED FACILITY OPERATING LICENSE NO. DPR-55  
DOCKET NO. 50-287

Replace the following page of the Appendix A Technical Specifications with the attached revised page. The revised page is identified by amendment number and contain marginal lines indicating the areas of change.

Remove

3.10.1-4

Insert

3.10.1-4

**SURVEILLANCE REQUIREMENTS (continued)**

SURVEILLANCE		FREQUENCY
SR 3.10.1.7	Verify the fuel oil transfer system operates to automatically transfer fuel oil from the storage tank to the day tank.	92 days
SR 3.10.1.8	Verify the fuel oil properties of the fuel oil stored in the day tank and underground storage tank are tested in accordance with, and maintained within the limits of the Diesel Fuel Oil Testing Program.	92 days
SR 3.10.1.9	<p>-----NOTES-----</p> <ol style="list-style-type: none"> <li>1. DG loadings may include gradual loading as recommended by the manufacturer.</li> <li>2. Momentary transients outside the load range do not invalidate this test.</li> <li>3. All DG starts may be preceded by an engine prelube period followed by a warmup period prior to loading.</li> </ol> <p>-----</p> <p>Verify the SSF DG is synchronized and loaded and operated for <math>\geq 60</math> minutes at a load <math>\geq 3280</math> kW.</p>	92 days
SR 3.10.1.10	Verify for required SSF battery that the cells, cell plates and racks show no visual indication of physical damage or abnormal deterioration that could degrade battery performance.	12 months

(continued)