

May 21, 2003

Mr. John L. Skolds, Chairman
and Chief Executive Officer
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: THREE MILE ISLAND NUCLEAR STATION, UNIT 1 (TMI-1), CYCLE 15 CORE
RELOAD DESIGN REQUEST FOR ADDITIONAL INFORMATION (RAI) (TAC
NO. MB7270)

Dear Mr. Skolds:

By letter dated January 16, 2003, you requested approval for changes to the TMI-1 Technical Specifications (TSs) associated with the Cycle 15 core reload design analysis. The Nuclear Regulatory Commission staff has reviewed your request and determined that it will need the additional information contained in the enclosure to complete its review. This information was faxed to your staff on May 5, 2003, in preparation for a May 13, 2003, conference call. As discussed with and agreed to by your staff during that call, you are requested to provide your response within 30 days of receipt of this request.

If you have any questions, please contact me at 301-415-1402.

Sincerely,

/RA/

Timothy G. Colburn, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-289

Enclosure: RAI

cc w/encl: See next page

May 21, 2003

Mr. John L. Skolds, Chairman
and Chief Executive Officer
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: THREE MILE ISLAND NUCLEAR STATION, UNIT 1 (TMI-1), CYCLE 15 CORE
RELOAD DESIGN REQUEST FOR ADDITIONAL INFORMATION (RAI) (TAC
NO. MB7270)

Dear Mr. Skolds:

By letter dated January 16, 2003, you requested approval for changes to the TMI-1 Technical Specifications (TSs) associated with the Cycle 15 core reload design analysis. The Nuclear Regulatory Commission staff has reviewed your request and determined that it will need the additional information contained in the enclosure to complete its review. This information was faxed to your staff on May 5, 2003, in preparation for a May 13, 2003, conference call. As discussed with and agreed to by your staff during that call, you are requested to provide your response within 30 days of receipt of this request.

If you have any questions, please contact me at 301-415-1402.

Sincerely,

/RA/

Timothy G. Colburn, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-289

Enclosure: RAI

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	JUhle	OGC	TColburn
PDI-1 Reading	SColpo	ACRS	MO'Brien
RLaufer	BPlatchek, Rgn-I		

DOCUMENT NAME: G:\PDI-1\TMI-1\MB7270RAI.WPD

Accession Number: ML031410680

*See previous concurrence

OFFICE	PDI-1/PM	PDI-1/LA	SRXB/SC	PDI-1/SC
NAME	TColburn	MO'Brien	JUhle*	RLaufer
DATE	5/14/03	5/14/03	05/14/03	5/21/03

OFFICIAL RECORD COPY

REQUEST FOR ADDITIONAL INFORMATION
REGARDING PROPOSED AMENDMENT TO TECHNICAL SPECIFICATIONS
IMPLEMENTATION OF STATISTICAL CORE DESIGN
THREE MILE ISLAND NUCLEAR STATION, UNIT 1

DOCKET NO. 50-289

By letter dated January 16, 2003, AmerGen Energy Company, LLC (the licensee) submitted a proposed amendment to the Technical Specifications (TSs) for Three Mile Island Nuclear Station, Unit 1 (TMI-1). The proposed amendment would implement the Statistical Core Design (SCD) Methodology described and approved in Framatome ANP Topical Report, BAW-10187P-A.

The Nuclear Regulatory Commission (NRC) staff has reviewed the information the licensee provided that supports the proposed TS changes. In order for the staff to complete its evaluation, the following additional information is requested:

1. As discussed in the NRC staff's letter dated March 24, 1993, that transmitted the safety evaluation for Topical Report BAW-10187P-A to Framatome ANP, the topical report is acceptable for referencing in license amendment applications to the extent specified, and under the limitations delineated in the report, and in the associated safety evaluation. Page 4 of Enclosure 1 of your submittal states that the restrictions specified in the approved topical report have been addressed in the core reload design analysis for TMI-1.

Please provide the information needed to justify your plant-specific application of this methodology by identifying any TMI-1 features or conditions outside the range of the generic assessment. Refer to Table 3-4 of BAW-10187P-A that specifies the range of applicability.

Additionally, the hot pin statistical design limit of 1.313 is acceptable with the following limitations. Please provide justification for your plant-specific application of this methodology.

- a. The component uncertainties and their distributions are to be reviewed on a plant-specific basis to determine their applicability.
- b. The "bounding" assembly-wise power distribution assumed in the core-wide SCD calculation should be shown to bound the expected operating power distributions on a cycle-specific basis.
- c. All core state variables that were not included in the statistical design must continue to be input to thermal-hydraulic computer codes at their most adverse allowable level rather than at their nominal value.

Enclosure

- d. The response surface model should be validated and revised (as necessary) when applied to new fuel assembly designs and extended operating conditions, and with new computer codes and departure from nucleate boiling (DNB) correlations. The approved

codes are LYNXT, LYNX1, and LYNX2, and the approved correlation is the BWC DNB correlation.

Three Mile Island Nuclear Station, Unit 1

cc:

Site Vice President - Three Mile Island Nuclear
Station, Unit 1

AmerGen Energy Company, LLC
P. O. Box 480

Middletown, PA 17057

Senior Vice President Nuclear Services
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President - Mid-Atlantic Operations Support
AmerGen Energy Company, LLC
200 Exelon Way, KSA 3-N
Kennett Square, PA 19348

Senior Vice President -
Mid Atlantic Regional Operating Group
AmerGen Energy Company, LLC
200 Exelon Way, KSA 3-N
Kennett Square, PA 19348

Vice President -
Licensing and Regulatory Affairs
AmerGen Energy Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Chairman
Board of County Commissioners
of Dauphin County
Dauphin County Courthouse
Harrisburg, PA 17120

Chairman
Board of Supervisors
of Londonderry Township
R.D. #1, Geyers Church Road
Middletown, PA 17057

Senior Resident Inspector (TMI-1)
U.S. Nuclear Regulatory Commission
P.O. Box 219
Middletown, PA 17057

Director - Licensing - Mid-Atlantic Regional
Operating Group
AmerGen Energy Company, LLC
Nuclear Group Headquarters
Correspondence Control
P.O. Box 160
Kennett Square, PA 19348

Rich Janati, Chief
Division of Nuclear Safety
Bureau of Radiation Protection
Department of Environmental Protection
Rachel Carson State Office Building
P.O. Box 8469
Harrisburg, PA 17105-8469

Three Mile Island Nuclear Station, Unit 1
Plant Manager
AmerGen Energy Company, LLC
P. O. Box 480
Middletown, PA 17057

Regulatory Assurance Manager - Three Mile
Island Nuclear Station, Unit 1
AmerGen Energy Company, LLC
P.O. Box 480
Middletown, PA 17057

John F. Rogge, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Michael A. Schoppman
Framatome ANP
Suite 705
1911 North Ft. Myer Drive
Rosslyn, VA 22209

Three Mile Island Nuclear Station, Unit 1

cc: continued

Vice President, General Counsel and Secretary
AmerGen Energy Company, LLC
2301 Market Street, S23-1
Philadelphia, PA 19101

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

Eric Epstein
TMI Alert
4100 Hillsdale Road
Harrisburg, PA 17112

Correspondence Control Desk

AmerGen Energy Company, LLC
200 Exelon Way, KSA 1-N
Kennett Square, PA 19348

Manager Licensing - Oyster Creek and Three Mile
Island

AmerGen Energy Company, LLC
Nuclear Group Headquarters
Correspondence Control
P.O. Box 160
Kennett Square, PA 19348