

MAY 14 2003



LR-N03-0224

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT
SALEM GENERATING STATION UNIT 2
DOCKET NO. 50-311**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 2 Technical Specifications, the operating statistics for **April 2003** are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "Lon Waldinger", written over a large, stylized circular flourish.

Lon Waldinger
Operations Director

JCN
Attachments

C Distribution

IE24

DOCKET NO.: 50-311
 UNIT: Salem 2
 DATE: 5/5/03
 COMPLETED BY: F. Todd
 TELEPHONE: (856) 339-1316

Reporting Period April 2003

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)
 Maximum Dependable Capacity (MWe-Net)
 No. of hours reactor was critical
 No. of hours generator was on line (service hours)
 Unit reserve shutdown hours
 Net Electrical Energy (MWH)

1131		
1092		
Month	Year-to-date	Cumulative
717	2810	123226
705	2797	119755
0	0	0
781894	3137839	122326814

UNIT SHUTDOWNS

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT
1	4/1/03 - 3/31/03	F	14	H	4	Multiple circulators o/s due to high grass levels

(1) Reason

A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training/License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other

(2) Method

1 - Manual
 2 - Manual Trip/Scram
 3 - Automatic Trip/Scram
 4 - Continuation
 5 - Other (Explain)

DOCKET NO.: 50-311
UNIT: Salem 2
DATE: 5/5/03
COMPLETED BY: J. Nagle
TELEPHONE: (856) 339-3171

Summary Of Monthly Operating Experience

- On April 1 the Unit returned to power from a shutdown due to 4 circulators out of service.