



Nebraska Public Power District

Always there when you need us

NLS2003043

May 19, 2003


U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555-0001

**Subject: Corrected Monthly Operating Report Data for May 2002 and November 2002,
Cooper Nuclear Station, Docket No. 50-298, DPR-46**

The purpose of this letter is to submit corrected information for the May 2002 and November 2002 Monthly Operating Reports. Attached are revised Appendix B's, Unit Shutdown Report, for May 2002 and November 2002 correcting unit shutdown data.

Should you have any comments or require additional information regarding this report, please contact Paul Fleming at (402) 825-2774.

Sincerely,



James A. Hutton
Plant Manager

/cb

Enclosure

cc: NRC Regional Administrator
NRC Senior Resident Inspector
ANI Library
J. M. Cline
A. L. Dostal
J. W. Dutton
R. L. Gumm
Records

W. J. Fehrman
W. D. Shanks
C. C. Warren
B. Lewis
G. W. Griffith
D. T. McNeil
INPO Records Center

IE24

APPENDIX B UNIT SHUTDOWNS

DOCKET NO.	050-0298
UNIT NAME	Cooper Nuclear Station
DATE	6/15/2002
COMPLETED BY	Rodrick Wilson
TELEPHONE	(402) 825-5135

REPORT MONTH May 2002

No.	Date	Type F: FORCED S: SCHEDULED	Duration (Hours)	Reason (1)	Method Of Shutting Down (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
02-01	05/10/02	S SCHEDULED	36.4	A	5	Generator taken offline during drywell entry for fan coil unit repairs. Rx remained critical
02-02	05/14/02	F FORCED	167.1	A	1	Failure of DEH system required plant shutdown for repairs

SUMMARY: On 5/10/02, CNS reduced power and took the generator offline to perform an online drywell entry to repair a fan coil unit. During this period, the Rx remained critical.
The generator was brought back online on 5/12/02 and power ascension began.
On 5/14/02, arcing in the 'B' phase of the potential transformer required a rapid drop in Rx power to again take the generator offline.
During the recovery from this, the DEH system failed and resulted in a manual Rx shutdown.

(1) Reason:
A - Equipment Failure (Explain)
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction
E - Operator Training/License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

(2) Method:
1 - Manual
2 - Manual Trip/Scram
3 - Automatic Trip/Scram
4 - Continuation
5 - Other (Explain)

APPENDIX B UNIT SHUTDOWNS

DOCKET NO.	050-0298
UNIT NAME	Cooper Nuclear Station
DATE	12/15/2002
COMPLETED BY	Rodrick Wilson
TELEPHONE	(402) 825-5135

REPORT MONTH November 2002

No.	Date	Type F: FORCED S: SCHEDULED	Duration (Hours)	Reason (1)	Method Of Shutting Down Reactor (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
02-03	11/09/02	S SCHEDULED	14.6	B	5	Rx remained critical while work on switchyard disconnect was performed

SUMMARY: On 11/09/02, CNS reduced power and took the generator offline to repair a hot disconnect in the switchyard.
The Rx remained critical during the maintenance activities.

(1) Reason:
 A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training/License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

(2) Method:
 1 - Manual
 2 - Manual Trip/Scram
 3 - Automatic Trip/Scram
 4 - Continuation
 5 - Other (Explain)

ATTACHMENT 3 LIST OF REGULATORY COMMITMENTS
--

Correspondence Number: NLS2003043

The following table identifies those actions committed to by Nebraska Public Power District (NPPD) in this document. Any other actions discussed in the submittal represent intended or planned actions by NPPD. They are described for information only and are not regulatory commitments. Please notify the NL&S Manager at Cooper Nuclear Station of any questions regarding this document or any associated regulatory commitments.

[illegible]