

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.5.1	Verify each AF manual, power operated, and automatic valve in each water flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position.	31 days
SR 3.7.5.2	Verify day tank contains $\geq 420$ gal of fuel oil.	31 days
SR 3.7.5.3	Operate the diesel driven AF pump for $\geq 15$ minutes.	31 days
SR 3.7.5.4	Verify the developed head of each AF pump at the flow test point is greater than or equal to the required developed head.	In accordance with the Inservice Testing Program
SR 3.7.5.5	Verify each AF automatic valve that is not locked, sealed, or otherwise secured in position, actuates to the correct position on an actual or simulated actuation signal.	18 months
SR 3.7.5.6	Verify each AF pump starts automatically on an actual or simulated actuation signal.	18 months
SR 3.7.5.7	Verify proper alignment of the required AF flow paths by verifying flow from the condensate storage tank to each steam generator.	Prior to entering MODE 2 whenever unit has been in MODE 5, MODE 6, or defueled for a cumulative period of > 30 days

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
SR 3.7.5.8    Verify fuel oil properties are tested in accordance with, and maintained within the limits of, the Diesel Fuel Oil Testing Program.	In accordance with the Diesel Fuel Oil Testing Program

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.7.5.1	Verify each AF manual, power operated, and automatic valve in each water flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position.	31 days
SR 3.7.5.2	Verify day tank contains $\geq 420$ gal of fuel oil.	31 days
SR 3.7.5.3	Operate the diesel driven AF pump for $\geq 15$ minutes.	31 days
SR 3.7.5.4	Verify the developed head of each AF pump at the flow test point is greater than or equal to the required developed head.	In accordance with the Inservice Testing Program
SR 3.7.5.5	Verify each AF automatic valve that is not locked, sealed, or otherwise secured in position, actuates to the correct position on an actual or simulated actuation signal.	18 months
SR 3.7.5.6	Verify each AF pump starts automatically on an actual or simulated actuation signal.	18 months
SR 3.7.5.7	Verify proper alignment of the required AF flow paths by verifying flow from the condensate storage tank to each steam generator.	Prior to entering MODE 2 whenever unit has been in MODE 5, MODE 6, or defueled for a cumulative period of $> 30$ days

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.7.5.8	Verify fuel oil properties are tested in accordance with, and maintained within the limits of, the Diesel Fuel Oil Testing Program.	In accordance with the Diesel Fuel Oil Testing Program