

From: Steven Long *NRP*
To: William Cullen *RES*
Date: 5/23/02 11:43AM
Subject: Fwd: Re: NRC Questions on Safety Significance Assessment (SSA)

Bill

William H. Cullen, Jr.
Materials Engineering Branch
Office of Nuclear Regulatory Research
Mail Stop: T-10 E10
Ph: 301 - 415 - 6754
FAX: 301 - 415 - 5151
whc@nrc.gov

>>> Douglas Pickett 05/23/02 09:51AM >>>
Steve Long -
Wally Norris -

✓ Please consider the attached in your discussions.

no action in this record was deleted
in accordance with the Freedom of Information
Act, exemptions *5*
FOIA- 2013-0019

Mark
m-4

From: <drwuokko@firstenergycorp.com>
To: "Douglas Pickett" <DVP1@nrc.gov>
Date: 5/23/02 9:48AM
Subject: Re: NRC Questions on Safety Significance Assessment (SSA)

FIRST ENERGY
NRC

release

Doug-

My understanding was the contractor's calculations were not "final" at this stage since there was to be a conference call between us to discuss assumptions, inputs, etc. If it turns out you can send us the calculations by the contractors but these would be made publicly available without appropriate input or assumptions having been used, we will want to discuss this before you release any of these to us. After you find out their availability, please call me and we can discuss.

Thanks.

-Dale Wuokko

"Douglas
Pickett" To: <drwuokko@firstenergycorp.com>
<DVP1@nrc.gov> cc: <Michael_k._leisure@firstenergycorp.com>
Subject: Re: NRC Questions on Safety Significance Assessment
05/23/2002 (SSA)
08:36 AM

Dale -

Thanks for your response. I've issued an all-points-bulletin for someone who can respond to item 1D of the RAI and whether our contractor's calculations can be made available to you (and I assume this means they will be made publicly available).

Doug

>>> <drwuokko@firstenergycorp.com> 05/23/02 08:19AM >>>

Doug-

We have two sets of questions from the NRC staff regarding the April 8, 2002 SSA: 1) Five questions that Region III provided under coverletter faxed on May 6, and 2) eight questions that were e-mailed by NRR and Research on May 15, 2002.

We expect to be able to provide a response to the five questions from Region III by June 7, except for "1.d". Question "1.d" requests we provide the estimated areas of exposed clad material that would cause the cladding to fail at normal operating pressure for clad thicknesses of 0.297" and 0.125". The April 8 SSA considered a fixed exposed clad area with cladding thicknesses cases of 0.297" and 0.240" to determine the maximum pressure carrying capability. The 0.240" value was the minimum cladding thickness

FIRST ENERGY

measured.

In order to respond to NRC question "1.d" we need to obtain from the NRC staff the assumption for the exposed cladding expansion shape; i.e., is it assumed the exposed cladding shape expands uniformly in each direction from the present triangular-like shape, expands in a circular shape, etc. Once this is firm'd up with the NRC staff, it will take approximately three weeks to have the results at Davis-Besse.

Regarding the questions from NRR and Research, these will be responded to after the above Region III questions have been answered (except for question 1.d). If possible, we would like a copy of the NRC staff contractor's calculations for comparison against our April 8 SSA submittal that included the calculations supporting our SSA.

Thanks.

-Dale Wuokko

CC: <tsswim@firstenergycorp.com>, <dhlockwood@firstenergycorp.com>, <spfrantz@firstenergycorp.com>, <meoreilly@firstenergycorp.com>, <mkleisure@firstenergycorp.com>