

June 5, 2003

Mr. J. A. Stall
Senior Vice President, Nuclear and
Chief Nuclear Officer
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

SUBJECT: TURKEY POINT PLANT UNITS 3 AND 4 - REQUEST FOR ADDITIONAL
INFORMATION REGARDING PROPOSED TECHNICAL SPECIFICATION
ADMINISTRATIVE CHANGES (TAC NOS. MB7148 AND MB7149)

Dear Mr. Stall:

By a letter dated December 20, 2002, Florida Power and Light Company submitted a request for proposed license amendments that would modify the Turkey Point Units 3 and 4 Technical Specifications. The U.S. Nuclear Regulatory Commission staff has reviewed the submittal and finds that a response to the enclosed request for additional information (RAI) is needed before we can complete the review.

This request was discussed with your staff on May 27, 2003, and Mr. Dave LaFleur agreed that a response would be provided within 60 days of the receipt of this letter. If you have any questions, please feel free to contact Mr. Michael Dudek at (301) 415-4016 or me at (301) 415-2315.

Sincerely,

/RA/

Eva A. Brown, Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-250 and 50-251

Enclosure: RAI

cc w/encl: See next page

June 5, 2003

Mr. J. A. Stall
Senior Vice President, Nuclear and
Chief Nuclear Officer
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

SUBJECT: TURKEY POINT PLANT UNITS 3 AND 4 - REQUEST FOR ADDITIONAL
INFORMATION REGARDING PROPOSED TECHNICAL SPECIFICATION
ADMINISTRATIVE CHANGES (TAC NOS. MB7148 AND MB7149)

Dear Mr. Stall:

By a letter dated December 20, 2002, Florida Power and Light Company submitted a request for proposed license amendments that would modify the Turkey Point Units 3 and 4 Technical Specifications. The U.S. Nuclear Regulatory Commission staff has reviewed the submittal and finds that a response to the enclosed request for additional information (RAI) is needed before we can complete the review.

This request was discussed with your staff on May 27, 2003, and Mr. Dave LaFleur agreed that a response would be provided within 60 days of the receipt of this letter. If you have any questions, please feel free to contact Mr. Michael Dudek at (301) 415-4016 or me at (301) 415-2315.

Sincerely,

/RA/

Eva A. Brown, Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-250 and 50-251

Enclosure: RAI

cc w/encl: See next page

Distribution:

PUBLIC	OGC	E. Brown	J. Munday, RII	A. Howe
PDII-2 R/F	ACRS	M. Dudek	B. Clayton (Hard copy)	

ADAMS ACCESSION NUMBER: ML031560014

OFFICE	PDII-2/Intern	PDII-2/PM	PDII-2/LA	PDII-2/SC
NAME	MDudek	EBrown	BClayton	AHowe
DATE	6/4/2003	6/4/2003	6/4/2003	6/4/2003

OFFICIAL RECORD COPY

REQUEST FOR ADDITIONAL INFORMATION
TECHNICAL SPECIFICATION ADMINISTRATIVE CHANGES
FLORIDA POWER AND LIGHT
TURKEY POINT PLANT UNITS 3 AND 4
DOCKET NOS. 50-250 AND 50-251

1. Change #7: Concerning the deletion of "below an average coolant temperature of 275°F," it appears that the Bases and Technical Specifications (TSs) disagree in wording.

- TSs use average coolant temperature of 275°F.
- Bases use less than or equal to coolant temperature of 275°F.

Provide an explanation for the discrepancy. (Title 10 of the *Code of Federal Regulation* (10 CFR) Section 50, Appendix G, and the American Society of Mechanical Engineers Boiler and Pressure Vessel Code Section XI, Appendix G, contain guidance for the origin and use of a coolant temperature of 275°F.)

2. Section 50.90 of 10 CFR requires that amendments to the license be fully described. Section 3.2 of the submittal discusses the types of editorial changes made and indicates that no specific justifications for the changes are provided. However, no marked-up TS pages were provided to show what editorial changes were made.

Provide the mark-ups of the editorial changes not submitted with the original application.

Enclosure

Mr. J. A. Stall
Florida Power and Light Company

cc:

M. S. Ross, Attorney
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

T. O. Jones, Site Vice President
Turkey Point Nuclear Plant
Florida Power and Light Company
9760 SW. 344th Street
Florida City, FL 33035

County Manager
Miami-Dade County
111 NW 1 Street, 29th Floor
Miami, Florida 33128

Senior Resident Inspector
Turkey Point Nuclear Plant
U.S. Nuclear Regulatory Commission
9762 SW. 344th Street
Florida City, Florida 33035

Mr. William A. Passetti, Chief
Department of Health
Bureau of Radiation Control
2020 Capital Circle, SE, Bin #C21
Tallahassee, Florida 32399-1741

Mr. Craig Fugate, Director
Division of Emergency Preparedness
Department of Community Affairs
2740 Centerview Drive
Tallahassee, Florida 32399-2100

TURKEY POINT PLANT

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

Plant General Manager
Turkey Point Nuclear Plant
Florida Power and Light Company
9760 SW. 344th Street
Florida City, FL 33035

Walter Parker
Licensing Manager
Turkey Point Nuclear Plant
9760 SW 344th Street
Florida City, FL 33035

Mr. William Jefferson
Vice President, Nuclear Operations Support
P.O. Box 14000
Juno Beach, FL 33408-0420

Mr. Rajiv S. Kundalkar
Vice President - Nuclear Engineering
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420