

From: Thomas Alexion
To: RSCHEID@ENTERGY.COM
Date: 5/6/03 11:42AM
Subject: FOLLOW-UP RAI ON POWER UPRATE STARTUP TESTING REPORT

Dick,

See the attached RAI.

Tom

FOLLOW-UP REQUEST FOR ADDITIONAL INFORMATION
POWER UPRATE STARTUP TESTING REPORT SUPPLEMENT
ARKANSAS NUCLEAR ONE, UNIT 2

By letter dated March 26, 2003 letter, you submitted additional information regarding your January 31, 2003, power uprate startup testing report. In that letter, you indicated that the vendor attributed the higher than anticipated differential pressure on the secondary side of the steam generator to uncertainties in pressure measurements and line loss estimates. You further indicated that you concluded that instrument error was not a significant contributor to the higher than anticipated differential pressure.

Since your March 26, 2003 letter, only ruled out instrument error as a possible cause of the higher than anticipated differential pressure, please clarify the cause for the higher than anticipated differential pressure. For example, was it attributable to line losses? If so, what was the cause for the higher than anticipated line losses?

Mail Envelope Properties (3EB7D7F6.650 : 0 : 20628)

Subject: FOLLOW-UP RAI ON POWER UPRATE STARTUP TESTING
REPORT

Creation Date: 5/6/03 11:42AM

From: Thomas Alexion

Created By: TWA@nrc.gov

Recipients	Action	Date & Time
ENTERGY.COM	Transferred	05/06/03 11:42AM
RSCHIED (RSCHIED@ENTERGY.COM)		

Post Office	Delivered	Route
		ENTERGY.COM

Files	Size	Date & Time
ANO2StartupRpt#2.wpd	2608	05/06/03 11:05AM
MESSAGE	718	05/06/03 11:42AM

Options

Auto Delete:	No
Expiration Date:	None
Notify Recipients:	Yes
Priority:	Standard
Reply Requested:	No
Return Notification:	None

Concealed Subject:	No
Security:	Standard

To Be Delivered:	Immediate
Status Tracking:	Delivered & Opened