

AmerGen Energy Company, LLC
Oyster Creek
US Route 9 South
P.O. Box 388
Forked River, NJ 08731-0388

An Exelon/British Energy Company

10 CFR 72.212(b)(1)(i)

May 30, 2003
2130-03-20153

United States Nuclear Regulatory Commission
Document Control Desk
Washington DC 20555

Subject: Oyster Creek Generating Station
Docket 72-15
Registration of Independent Spent Fuel Storage Installation
Casks No. 7 and No. 8

In accordance with 10 CFR 72.212(b)(1)(I), this letter docket the use of the following casks in the Oyster Creek Generating Station Independent Spent Fuel Storage Installation:

<u>Cask Certificate No.</u>	<u>Cask Model No.</u>	<u>Cask ID No.</u>	<u>Date Loaded</u>
72-1004 (Amendment 4)	NUHOMS-61BT	OCG61B-007-C	05/10/2003
72-1004 (Amendment 4)	NUHOMS-61BT	OCG61B-008-C	05/18/2003

Additionally, the following thermal performance data was collected.

<u>Cask / Horizontal Storage Module No.</u>	<u>OCG61B-007-C/HSM-915-007</u>
Decay Heat Load	16.7 KW
Forecast Temperature Rise	70 Degrees F
Actual Temperature Rise	38 Degrees F
<u>Cask / Horizontal Storage Module No.</u>	<u>OCG61B-008-C/HSM-915-008</u>
Decay Heat Load	16.5 KW
Forecast Temperature Rise	70 Degrees F
Actual Temperature Rise	40.4 Degrees F

If any further information or assistance is required, please contact Mr. William Stewart of my staff at 609.971.4775.

Very truly yours,



Ernest J. Harkness P.E., Vice President
Oyster Creek Generating Station

EJH/GWB

nmssol

Registration ISFSI Casks 7 and 8
May 30, 2003
2130-03-20153
Page 2

10 CFR 72.212(b)(1)(I)

cc: Administrator, Region I
NRC Senior Project Manager
NRC Senior Resident Inspector
Spent Fuel Project Office, Steve O'Connor