

### 3.6 CONTAINMENT SYSTEMS

#### 3.6.2.2 Suppression Pool Water Level

LCO 3.6.2.2      Suppression pool water level shall be:  
                     a.  $\geq 18$  ft 11 inches and  $\leq 19$  ft 5 inches,  
                     b.  $\geq 18$  ft 11 inches and  $\leq 20$  ft 1 inches, in MODE 3 with  
                                 reactor pressure less than 235 psig

APPLICABILITY:    MODES 1, 2, and MODE 3.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Suppression pool water level not within limits.	A.1      Restore suppression pool water level to within limits.	2 hours
	OR	
B. Required Action and associated Completion Time not met.	B.1      Be in MODE 3.	12 hours
	<u>AND</u> B.2      Be in MODE 4.	36 hours

#### SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.2.2.1      Verify suppression pool water level is within limits.	24 hours

### 3.6 CONTAINMENT SYSTEMS

#### 3.6.2.4 Suppression Pool Makeup (SPMU) System

LCO 3.6.2.4 Two SPMU subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Combined upper containment pool and suppression pool water levels not within limit.	A.1 Restore upper containment pool and suppression pool water levels to within limit.	4 hours
B. Upper containment pool water temperature not within limit.	B.1 Restore upper containment pool water temperature to within limit.	24 hours
C. One SPMU subsystem inoperable for reasons other than Condition A or B.	C.1 Restore SPMU subsystem to OPERABLE status.	7 days
D. Required Action and associated Completion Time not met.	D.1 Be in MODE 3.	12 hours
	<u>AND</u> D.2 Be in MODE 4.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.6.2.4.1 Verify upper containment pool water level is:</p> <ul style="list-style-type: none"> <li>a. <math>\geq</math>el. 825 ft 6 inches;</li> <li>b. <math>\geq</math>el. 825 ft 10 inches when the inclined fuel transfer pool to steam dryer storage pool gate is not open; and</li> <li>c. <math>\geq</math>el. 827 ft 1 inch when the reactor cavity to steam dryer storage pool gate is not open.</li> </ul> <p><u>OR</u></p> <ul style="list-style-type: none"> <li>d. Reactor cavity pool level <math>\geq</math> el. 824 ft 7 inches in MODE 3 with reactor pressure less than 235 psig.</li> </ul> <p><u>OR</u></p> <ul style="list-style-type: none"> <li>e. Suppression pool water level <math>\geq</math> 19 ft 9 inches in MODE 3 with reactor pressure less than 235 psig.</li> </ul>	<p>24 hours</p>
<p>SR 3.6.2.4.2 Verify upper containment pool water temperature is <math>\leq 120^{\circ}\text{F}</math>.</p>	<p>24 hours</p>
<p>SR 3.6.2.4.3 Verify each SPMU subsystem manual, power operated, and automatic valve that is not locked, sealed, or otherwise secured in position is in the correct position.</p>	<p>31 days</p>
<p>SR 3.6.2.4.4 -----NOTE----- Actual makeup to the suppression pool may be excluded. -----</p> <p>Verify each SPMU subsystem automatic valve actuates to the correct position on an actual or simulated automatic initiation signal.</p>	<p>18 months</p>