

July 2, 2003

MEMORANDUM TO: James W. Clifford, Chief, Section 2  
Project Directorate I  
Division of Licensing Project Management

FROM: Victor Nerses, Senior Project Manager, Section 2 */RA/*  
Project Directorate I  
Division of Licensing Project Management

SUBJECT: SUMMARY OF JUNE 12, 2003 PUBLIC MEETING WITH FPL ENERGY, LLC, REGARDING SEABROOK STATION PROPOSED INSTALLATION OF A 5MW SUPPLEMENTARY NON-SAFETY RELATED POWER SUPPLY (TAC NO. MB9116)

On June 12, 2003, the U.S. Nuclear Regulatory Commission (staff) met with representatives of FPL Energy, LLC to discuss their plans for installing a supplementary power supply, consisting of two diesel generators with a combined power output of approximately 5MW at Seabrook Station. The licensee provided an overview of the project and a schedule for submitting an amendment request to make a change to their license to include this supplementary power supply. The licensee and staff discussed the items and issues the amendment request should address.

The licensee stated that the purpose of installing the supplementary power supply would be to extend the allowed outage time for their safety-related emergency diesel generators, and to decrease Seabrook Station's core damage frequency.

The licensee noted that a similar amendment request was granted to Waterford on July 21, 2000, and that Crystal River has a similar amendment request currently under review. In response to this, the staff suggested that the licensee address all issues raised in the requests for additional information relating to the Waterford amendment and the Crystal River amendment request when submitting their amendment request.

After the initial presentation by the licensee, a discussion was held on specific issues related to this proposed supplementary power supply. Items that were discussed included updating procedures for use of a supplementary power supply, possible common cause failure, and isolation of non-safety-related power buses from safety-related buses. The licensee agreed to address the discussed issues in its planned submittal.

A list of attendees and the slides used during the meeting are available in the Agencywide Document Access and Management System under accession numbers ML031740431 and ML031740421.

cc: See next page

July 2, 2003

MEMORANDUM TO: James W. Clifford, Chief, Section 2  
Project Directorate I  
Division of Licensing Project Management

FROM: Victor Nerses, Senior Project Manager, Section 2 */RA/*  
Project Directorate I  
Division of Licensing Project Management

SUBJECT: SUMMARY OF JUNE 12, 2003 PUBLIC MEETING WITH FPL ENERGY, LLC, REGARDING SEABROOK STATION PROPOSED INSTALLATION OF A 5MW SUPPLEMENTARY NON-SAFETY RELATED POWER SUPPLY (TAC NO. MB9116)

On June 12, 2003, the U.S. Nuclear Regulatory Commission (staff) met with representatives of FPL Energy, LLC to discuss their plans for installing a supplementary power supply, consisting of two diesel generators with a combined power output of approximately 5MW at Seabrook Station. The licensee provided an overview of the project and a schedule for submitting an amendment request to make a change to their license to include this supplementary power supply. The licensee and staff discussed the items and issues the amendment request should address.

The licensee stated that the purpose of installing the supplementary power supply would be to extend the allowed outage time for their safety-related emergency diesel generators, and to decrease Seabrook Station's core damage frequency.

The licensee noted that a similar amendment request was granted to Waterford on July 21, 2000, and that Crystal River has a similar amendment request currently under review. In response to this, the staff suggested that the licensee address all issues raised in the requests for additional information relating to the Waterford amendment and the Crystal River amendment request when submitting their amendment request.

After the initial presentation by the licensee, a discussion was held on specific issues related to this proposed supplementary power supply. Items that were discussed included updating procedures for use of a supplementary power supply, possible common cause failure, and isolation of non-safety-related power buses from safety-related buses. The licensee agreed to address the discussed issues in its planned submittal.

A list of attendees and the slides used during the meeting are available in the Agencywide Document Access and Management System under accession numbers ML031740431 and ML031740421.

cc: See next page

#### DISTRIBUTION

PUBLIC	PDI-2 Reading	VNerses	GMiller	CRaynor	AGill
OChopra	APal	RJenkins	MMcConnell	CHolden	JClifford
TMarsh	TMensah	OGC	ACRS	TMcGinty, Rgn1	BMcDermott, Rgn1
MKotzalas	JBoska	JCalvo	JJolicoeur	CLiang	HNieh

Accession No.: ML031671260

OFFICE	PDI-2/PM	PDI-2/PM	PDI-2/LA	PDI-2/SC
NAME	GMiller	VNerses	CRaynor	JClifford
DATE	7/1/03	7/1/03	7/1/03	7/2/03

OFFICIAL RECORD COPY

Seabrook Station, Unit No. 1

cc:

Mr. J. A. Stall  
Senior Vice President, Nuclear and  
Chief Nuclear Officer  
Florida Power & Light Company  
P.O. Box 14000  
Juno Beach, FL 33408-0420

Mr. Peter Brann  
Assistant Attorney General  
State House, Station #6  
Augusta, ME 04333

Resident Inspector  
U.S. Nuclear Regulatory Commission  
Seabrook Nuclear Power Station  
P.O. Box 1149  
Seabrook, NH 03874

Town of Exeter  
10 Front Street  
Exeter, NH 03823

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Office of the Attorney General  
One Ashburton Place, 20th Floor  
Boston, MA 02108

Board of Selectmen  
Town of Amesbury  
Town Hall  
Amesbury, MA 01913

Mr. Dan McElhinney  
Federal Emergency Management Agency  
Region I  
J.W. McCormack P.O. &  
Courthouse Building, Room 401  
Boston, MA 02109

Mr. Jack Devine  
Polestar Applied Technology  
One First Street, Suite 4  
Los Altos, CA 94019

Mr. Stephen McGrail, Director  
ATTN: James Muckerheide  
Massachusetts Emergency Management Agency  
400 Worcester Road  
Framingham, MA 01702-5399

Philip T. McLaughlin, Attorney General  
Steven M. Houran, Deputy Attorney  
General  
33 Capitol Street  
Concord, NH 03301

Mr. Donald Bliss, Director  
New Hampshire Office of Emergency  
Management  
State Office Park South  
107 Pleasant Street  
Concord, NH 03301

Mr. Daniel G. Roy  
Nuclear Training Manager  
Seabrook Station  
FPL Energy Seabrook, LLC  
P.O. Box 300  
Seabrook, NH 03874

Mr. Gene F. St. Pierre  
Station Director  
Seabrook Station  
FPL Energy Seabrook, LLC  
P.O. Box 300  
Seabrook, NH 03874

Mr. M. S. Ross, Attorney  
Florida Power & Light Company  
P.O. Box 14000  
Juno Beach, FL 33408-0420

Mr. Rajiv S. Kundalkar  
Vice President - Nuclear Engineering  
Florida Power & Light Company  
P.O. Box 14000  
Juno Beach, FL 33408-0420