

Exelon Nuclear
Limerick Generating Station
P.O. Box 2300
Pottstown, PA 19464

www.exeloncorp.com

T.S. 6.9.1.6

June 13, 2003

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Limerick Generating Station, Units 1 and 2
Facility Operating License Nos. NPF-39 and NPF-85
NRC Docket Nos. 50-352 and 50-353

Subject: Monthly Operating Report for May 2003

Attached is the monthly operating report for Limerick Units 1 and 2 for the month of May 2003 forwarded pursuant to Technical Specification 6.9.1.6 and the guidance of NRC Generic Letter 97-02.

If you have any questions or require additional information, please do not hesitate to contact us.

Sincerely,



Bryan C. Hanson
Plant Manager

Attachments

cc: H. Miller, Administrator, Region I, USNRC
A. Burritt, LGS USNRC Senior Resident Inspector

JE24

bcc: R. Braun - GML 5-1
B. Hanson - GML 5-1
C. Mudrick - SSB 3-1
E. Kelly - SSB 3-1
K. Kemper - SSB 2-4
S. Gamble - SSB 2-4
R. McCall - SSB 2-3
J. Toro - SMB 1-2
G. Lee - SSB 3-1
J. Grimes - KSA 2N
J. Humphreys - KSA 3G
D. Dyckman (PABRP) SSB 2-4

Unit: Limerick 1
Docket No: 50-352
Date: 6/13/03
Completed by: Greg Lee
Telephone: (610) 718-3707

A. OPERATING DATA
REPORT REPORTING PERIOD-May 2003

Design Electrical Rating (MWe-Net)	1191
Maximum Dependable Capacity (MWe-Net)	1134

	Month	Year to Date	Cumulative
Hours Reactor Critical (Hours)	744.0	3,561.1	133,429.5
Hours Generator On-Line (Hours)	744.0	3,535.1	131,444.2
Unit Reserve Shutdown Hours (Hours)	0.0	0.0	0.0
Net Electrical Energy (MWh)	865,174	4,134,176	135,903,000

B. UNIT SHUTDOWN

No.	Date (yymmdd)	Type	Generator Off-line Duration (hrs)	Reason	Method	Corrective Actions/Comments
			None During May 2003			

SUMMARY

Unit 1 began the month of May 2003 at 100% of rated thermal power (RTP).

On May 17th at 08:52 hours, reactor power was reduced to 81% RTP for MSIV & turbine valve testing, scram time testing and rod pattern adjustment.

On May 18th at 17:44 hours, reactor power was restored to 100% RTP.

Unit 1 ended the month of May 2003 at 100% RTP.

Type
F-Forced
S-Scheduled

Reason
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training/License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

Method
1-Manual
2-Manual Trip/Scram
3-Automatic Trip/Scram
4-Continuation
5-Other (Explain)

C. SAFETY/RELIEF VALVE OPERATION

Date	Valves Actuated	No. & Type of Actuation	Plant Condition	Description of Event
		None During May 2003		

Unit: Limerick 2
Docket No: 50-353
Date: 6/13/03
Completed by: Greg Lee
Telephone: (610)718-3707

A. OPERATING DATA
REPORT REPORTING PERIOD-May 2003

Design Electrical Rating (MWe-Net)	1191
Maximum Dependable Capacity (MWe-Net)	1134

	Month	Year to Date	Cumulative
Hours Reactor Critical (Hours)	744.0	3,185.6	109,313.1
Hours Generator On-Line (Hours)	744.0	3,142.7	107,577.7
Unit Reserve Shutdown Hours (Hours)	0.0	0.0	0.0
Net Electrical Energy (MWh)	849,595	3,533,918	115,168,161

B. UNIT SHUTDOWN

No.	Date (yymmdd)	Type	Generator Off-line Duration (hrs)	Reason	Method	Corrective Actions/Comments
			None During May 2003			

SUMMARY

Unit 2 began the month of May 2003 at 100% of rated thermal power (RTP).

On May 23rd at 14:27 hours, reactor power was reduced to 98% RTP for recirculation flow controller repair. At 15:20 hours, reactor power was restored to 100% RTP. At 22:00 hours, reactor power was reduced to 59% RTP for MSIV & turbine valve testing, scram time testing, and 2C condensate pump repair.

On May 27th at 02:34 hours, reactor power was restored to 100% RTP.

Unit 2 ended the month of May 2003 at 100% RTP.

Type	Reason	Method
F-Forced	A-Equipment Failure (Explain)	1-Manual
S-Scheduled	B-Maintenance or Test	2-Manual Trip/Scram
	C-Refueling	3-Automatic Trip/Scram
	D-Regulatory Restriction	4-Continuation
	E-Operator Training/License Examination	5-Other (Explain)
	F-Administrative	
	G-Operational Error (Explain)	
	H-Other (Explain)	

C. SAFETY/RELIEF VALVE OPERATION

Date	Valves Actuated	No. & Type of Actuation	Plant Condition	Description of Event
		None During May 2003		