



JUN 11 2003


L-2003-148  
10 CFR 50.36

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Monthly Operating Report - May 2003

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the May 2003 Operating Data Reports and Summaries of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

  
Terry O. Jones  
Vice President  
Turkey Point Plant

LDT

Attachments

NRC Regulatory Issue Summary 2001-05 waived the requirements that multiple copies of documents be submitted to the NRC.

IE24

DOCKET NO.: 50-250  
 UNIT: Turkey Point Unit 3  
 DATE: 6/3/2003  
 COMPLETED BY: Linda Tudor  
 TELEPHONE: (305) 246-6408

Reporting Period May, 2003

### OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	707.0	2856.4	197396.2
No. of hours generator was on line (service hours)	698.7	2814.5	195023
Unit reserve shutdown hours	0	0	121.8
Net Electrical Energy (MWH)	480597	1874007	127233084

### UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
20030015	5/20/03	F	23.27	A	1	Manual reactor shutdown due to Shutdown Bank B not able to move on demand. Shutdown Bank B was repaired and the unit was returned to Mode 1 on 5/21/03.

**(1) Reason**

A - Equipment Failure (Explain)  
 B - Maintenance or Test  
 C - Refueling  
 D - Regulatory Restriction  
 E - Operator Training/License Examination  
 F - Administrative  
 G - Operational Error (Explain)  
 H - Other

**(2) Method**

1 - Manual  
 2 - Manual Trip/Scram  
 3 - Automatic Trip/Scram  
 4 - Continuation  
 5 - Other (Explain)

### Summary Of Monthly Operating Experience

Unit 3 returned to power operation on 5/1/03 after repairs to CV-3-200B. Unit 3 remained at essentially 100% power until 5/20/03. On 5/20/03, Unit 3 performed a manual reactor shutdown to repair Rod Control Shutdown Bank B. Unit 3 returned to power operation on 5/21/03 and remained at essentially 100% power for the remainder of the month of May 2003.

DOCKET NO.: 50-251  
 UNIT: Turkey Point Unit 4  
 DATE: 06/03/03  
 COMPLETED BY: Linda Tudor  
 TELEPHONE: (305) 246-6408

Reporting Period May, 2003

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	744	3623	194985.7
No. of hours generator was on line (service hours)	744	3623	190568.2
Unit reserve shutdown hours	0	0	577.2
Net Electrical Energy (MWH)	521823	2545090	125504180

#### UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

#### (1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

#### (2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

#### Summary Of Monthly Operating Experience

Unit 4 operated at essentially 100% power for the month of May 2003.