



444 South 16th Street Mall
Omaha NE 68102-2247

June 10, 2003
LIC-03-0086

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20535-0001

Reference: Docket No. 50-285

SUBJECT: May 2003 Monthly Operating Report (MOR)

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPD) submits the attached MOR for May 2003. No commitments are made to the NRC in this letter.

If you have any questions, please contact Mr. Erick Matzke at (402) 533-6855.

Sincerely,

R. P. Clemens
Division Manager
Nuclear Assessments

RPC/EPM/epm

Attachment

c: T. P. Gwynn, Acting NRC Regional Administrator, Region IV
A. B. Wang, NRC Project Manager
J. G. Kramer, NRC Senior Resident Inspector
INPO Records Center

IE24

LIC-03-0086

Attachment

OPERATING DATA REPORT

DOCKET NO. 50-285
UNIT NAME Fort Calhoun Station
DATE June 2, 2003
COMPLETED BY E. P. Matzke
TELEPHONE (402) 533-6855

REPORT PERIOD: May 2003

Design Electrical Rating (MWe-Net): 478
Maximum Dependable Capacity (MWe-Net): 478

	<u>MONTH</u>	<u>YR-TO-DATE</u>	<u>CUMULATIVE</u>
Number of Hours Reactor was Critical:	744	3624	210,866
Number of Hours Generator was On-line:	744	3624	209,552
Unit Reserve Shutdown Hours:			
Net Electrical Energy Generated (MWh):	360,798	1,684,843	90,700,873

UNIT SHUTDOWNS

No.	Date (yy/mm/dd)	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action Comments

(1) Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2) Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

OPERATIONS SUMMARY

The Fort Calhoun Station operated at 100% power the entire month.

SAFETY VALVE OR PORV CHALLENGES/FAILURES

No failures or challenges to safety valves or PORVs occurred during the month.