

PLANT SYSTEMS

MAIN STEAM LINE ISOLATION VALVES

LIMITING CONDITION FOR OPERATION

3.7.1.5 Each main steam line isolation valve shall be OPERABLE.

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

MODES 1 - With one main steam line isolation valve inoperable but open, POWER OPERATION may continue provided the inoperable valve is restored to OPERABLE status within 4 hours;

Otherwise, be in HOT SHUTDOWN within the next 12 hours.

MODES 2 - With one main steam line isolation valve inoperable, and 3 subsequent operation in MODES 2 or 3 may proceed after:

a. The inoperable isolation valve is restored to OPERABLE status, or

b. The isolation valve is maintained closed;

Otherwise, be in HOT SHUTDOWN within the next 12 hours.

SURVEILLANCE REQUIREMENTS

4.7.1.5 Each main steam line isolation valve shall be demonstrated OPERABLE by verifying full closure within 6 seconds when tested pursuant to Specification 4.0.5.