

Edward M. Root
Manager - Radwaste, Environmental, Chemistry

440-280-5646
Fax: 440-280-5681

June 30, 2003
PY-CEI/OEPA-0402L


Ohio Environmental Protection Agency
Division of Water Pollution Control
Enforcement Section, ES/MOR
P. O. Box 1049
Columbus, OH 43216-1049

Ladies and Gentlemen,

The Preliminary Effluent Limit (PEL) for copper was exceeded during the month June 2003. This letter serves as the written notification in accordance with Part II of National Pollutant Discharge Elimination System (NPDES) Permit 3IB00016*GD. The monthly copper samples were performed on June 4, 2003, and the samples were analyzed on June 6, 2003. The outfall sample (004) was 41 ug/l, exceeding the PEL of 38 ug/l. This coincided with a large increase of the lake water copper, which was 30 ug/l for the June 2003 sample, but had been averaging less than 10 ug/l for the previous four months. The Perry Nuclear Power Plant (PNPP) began monitoring copper in July 2002, and has observed small increases in copper levels from the intake to the outfall. PNPP does not add any additive that contains copper. It is currently believed that the increase of copper levels from intake to outfall is due to the constituents of the cooling water system materials or concentration of Lake Water copper in the cooling tower. It is expected that copper levels will decrease below the current PEL, as intake copper levels decrease. PNPP will be performing samples inside the cooling water systems to locate the cause for the small increases of copper from intake to outfall. It is believed this data will aid in determining future permit requirements and limits. The monthly sample data will also be included in the June NPDES report.

If you have questions or require additional information, please contact Mr. Leo Harte at (440) 280-5514.

Very Truly Yours,



cc: OEPA Northeast District Office
NRC Region III
NRC Resident Inspector
NRC Project Manager
NRC Document Control Desk (Docket No. 50-440)

JE25