



Progress Energy

JUL 14 2003

SERIAL: BSEP 03-0108

**U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001**

**BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324/LICENSE NOS. DPR-71 AND DPR-62
JUNE 2003 MONTHLY OPERATING REPORTS**

Ladies and Gentlemen:

In accordance with Technical Specification (TS) 5.6.4 for the Brunswick Steam Electric Plant (BSEP), Unit Nos. 1 and 2, Progress Energy Carolinas, Inc. is submitting the enclosed Monthly Operating Reports for June 2003. These reports are being submitted to the NRC by the 15th day of the month following the calendar month covered by the reports, as specified in TS 5.6.4.

There are no regulatory commitments being made in this submittal. Please refer questions regarding this submittal to Mr. Leonard R. Beller, Supervisor – Licensing/Regulatory Programs, at (910) 457-2073.

Sincerely,

**Edward T. O'Neil
Manager - Support Services
Brunswick Steam Electric Plant**

DRC/drc

Enclosures:

- 1. BSEP, Unit No. 1 Monthly Operating Report June 2003**
- 2. BSEP, Unit No. 2 Monthly Operating Report June 2003**

IE24

Document Control Desk
BSEP 03-0108 Page 2

cc (with enclosures):

U. S. Nuclear Regulatory Commission, Region II
ATTN: Mr. Luis A. Reyes, Regional Administrator
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, GA 30303-8931

U. S. Nuclear Regulatory Commission
ATTN: NRC Resident Inspector
8470 River Road
Southport, NC 28461-8869

U. S. Nuclear Regulatory Commission
ATTN: Ms. Brenda L. Mozafari (Mail Stop OWFN 8G9) (Electronic Copy Only)
11555 Rockville Pike
Rockville, MD 20852-2738

Ms. Jo A. Sanford
Chair - North Carolina Utilities Commission
P.O. Box 29510
Raleigh, NC 27626-0510

ElectriCities of N. C., Inc.
ATTN: Mr. Roy Donehower
P. O. Box 29513
Raleigh, NC 27626-0513

APPENDIX A OPERATING DATA REPORT

DOCKET NO. 50-325
UNIT NAME Brunswick Steam Electric Plant, Unit No. 1
DATE July 9, 2003
COMPLETED BY Kester M. Thompson
TELEPHONE (910) 457-2754

REPORTING PERIOD June 2003
 (Month/Year)

	MONTH	YEAR TO DATE	CUMULATIVE
1. Design Electrical Rating: (MWe-Net) – Note 1	895	N/A	N/A
2. Maximum Dependable Capacity: (MWe-Net) – Note 2	872	N/A	N/A
3. Number of Hours the Reactor Was Critical:	720	4,317.6	165,232.3
4. Number of Hours the Generator Was On Line:	720	4,305.1	160,756.3
5. Unit Reserve Shutdown Hours:	0	0	0
6. Net Electrical Energy (MWH):	639,522	3,860,301	119,907,737

Note 1: License Amendment 222 for Unit 1 approved Extended Power Uprate (EPU). This amendment was implemented on June 1, 2002. As a result, the present value for Design Electrical Rating (i.e., net megawatts electric (MWe)) has been revised from 867 MWe to 895 MWe to reflect current equipment limitations and testing activities associated with the first phase of EPU implementation. The Design Electrical Rating value is subject to further revision as EPU testing and implementation activities continue.

Note 2: A new Maximum Dependable Capacity of 872 MWe-Net has been established for Unit 1 effective January 2003. This value is subject to further revision as EPU implementation activities continue.

APPENDIX B UNIT SHUTDOWNS

DOCKET NO. 50-325
UNIT NAME Brunswick Steam Electric Plant, Unit No. 1
DATE July 9, 2003
COMPLETED BY Kester M. Thompson
TELEPHONE (910) 457-2754

REPORTING PERIOD June 2003
(Month/Year)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
						Unit No. 1 was not required to shut down during the month of June 2003.

SUMMARY:

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

**APPENDIX A
OPERATING DATA REPORT**

DOCKET NO. 50-324
UNIT NAME Brunswick Steam Electric Plant, Unit No. 2
DATE July 9, 2003
COMPLETED BY Kester M. Thompson
TELEPHONE (910) 457-2754

REPORTING PERIOD June 2003
(Month/Year)

	MONTH	YEAR TO DATE	CUMULATIVE
1. Design Electrical Rating: (MWe-Net) – Note 1	935	N/A	N/A
2. Maximum Dependable Capacity: (MWe-Net)	811	N/A	N/A
3. Number of Hours the Reactor Was Critical:	720	3,712.6	174,007.8
4. Number of Hours the Generator Was On Line:	720	3,647.3	167,960.0
5. Unit Reserve Shutdown Hours:	0	0	0
6. Net Electrical Energy (MWH):	637,351	3,097,963	120,123,373

Note 1: License Amendment 247 for Unit 2 approved Extended Power Uprate (EPU). This amendment was implemented on March 8, 2003. As a result, the present value for Design Electrical Rating (i.e., net megawatts electric (MWe)) has been revised from 867 MWe to 935 MWe to reflect current equipment limitations and testing activities associated with the first phase of EPU implementation. The Design Electrical Rating value is subject to further revision as EPU testing and implementation activities continue

**APPENDIX B
UNIT SHUTDOWNS**

DOCKET NO. 50-324
UNIT NAME Brunswick Steam Electric Plant, Unit No. 2
DATE July 9, 2003
COMPLETED BY Kester M. Thompson
TELEPHONE (910) 457-2754

REPORTING PERIOD June 2003
(Month/Year)

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
						Unit No. 2 was not required to shut down during the month of June 2003.

SUMMARY:**(1) Reason**

A - Equipment Failure (Explain)
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction
E - Operator Training/License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

(2) Method

1 - Manual
2 - Manual Trip/Scram
3 - Automatic Trip/Scram
4 - Continuation
5 - Other (Explain)