



**State of New Jersey**

James E. McGreevey  
Governor

Department of Environmental Protection  
Division of Environmental Safety and Health  
Radiation Protection and Release Prevention Element  
Bureau of Nuclear Engineering  
P. O. Box 415  
Trenton, New Jersey 08625-0415  
Tel (609) 984-7700  
Fax (609) 984-7513

Bradley M. Campbell  
Commissioner

July 18, 2003

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Dear Sir:

Subject: Hope Creek Generating Station  
Docket No. 50-354  
License Change Request H03-05  
Request for Change to Technical Specifications  
Control Room Emergency Filtration System

PSEG Nuclear LLC submitted the proposed change to the Hope Creek Technical Specifications by letter to the NRC dated July 9, 2003. The proposed change would revise Technical Specification 3.7.2, Control Room Emergency Filtration System by changing the allowable time that one control room emergency filtration subsystem due to an inoperable chiller unit from 7 days to 30 days.

The BNE has no comments on the proposed change. If you need to discuss the subject further, please contact Elliot Rosenfeld at (609) 984-7548.

Sincerely,

Kent W. Tosch, Manager  
Bureau of Nuclear Engineering

A002

**Ditribution**

**Dr. Jill Lipoti, DEP**

**Dennis Zannoni, DEP**

**Dr. Robert Bores, NRC**

**Richard Ennis, NRC Licensing Project Manager**

**Mel Gray, Sr Resident Inspector**

**Gabor Salamon, PSEG Nuclear LLC**