

**From:** Thomas Alexion  
**To:** BENNETT, STEVE A  
**Date:** 7/14/03 9:26AM  
**Subject:** Third RAI on Relaxation Requests

Steve,

See the attached.

Tom

**Mail Envelope Properties (3F12AF82.742 : 0 : 20628)**

**Subject:** Third RAI on Relaxation Requests  
**Creation Date:** 7/14/03 9:26AM  
**From:** Thomas Alexion

**Created By:** TWA@nrc.gov

<b>Recipients</b>	<b>Action</b>	<b>Date &amp; Time</b>
entergy.com	Transferred	07/14/03 09:26AM
SBENNE2 (BENNETT, STEVE A)		

<b>Post Office</b>	<b>Delivered</b>	<b>Route</b>
		entergy.com

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
CombinationRAI.wpd	3237	07/14/03 09:23AM
MESSAGE	715	07/14/03 09:26AM

**Options**

<b>Auto Delete:</b>	No
<b>Expiration Date:</b>	None
<b>Notify Recipients:</b>	Yes
<b>Priority:</b>	Standard
<b>Reply Requested:</b>	No
<b>Return Notification:</b>	None

<b>Concealed Subject:</b>	No
<b>Security:</b>	Standard

<b>To Be Delivered:</b>	Immediate
<b>Status Tracking:</b>	Delivered & Opened

**Request for Additional Information (RAI) and Comments Regarding Entergy Letter  
CNRO-2003-00027 (July 1, 2003), In Regard to Reactor Pressure Vessel Penetration  
Nozzle Inspection Using a Combination of NDE Methods  
Arkansas Nuclear One (ANO), Units 1 and 2, and Waterford**

1. The licensee is requested to provide a table at the completion of the outage, listing each of the nozzles and the inspection method or combination of inspection methods that were performed for each Unit from ANO and Waterford, respectively.
2. The licensee is requested to provide justification for the need to perform a combination of inspections. Identify the limitations on the nozzles that require a combination of inspections (i.e., funnels, threads thermal sleeves, etc.).
3. The licensee is requested to confirm that with a combination of inspection methods (i.e., Item 3 under Proposed Alternative), each nozzle will have complete coverage of the areas of concern (subject to any approved relaxations) as identified in the Order. Item 3 under Proposed Alternatives should clarify the scope for each examination method (as written the scope is not sufficient for ECT or PT), or adopt wording similar to that in the DC Cook relaxation request.