

From: Thomas Alexion
To: BOYD, DENNIS W
Date: 7/23/03 8:28AM
Subject: CONTAINMENT SPRAY SYSTEM SURVEILLANCE LICENSE AMENDMENT
REQUEST

Dennis,

See the attached, revised, RAI from Reactor Systems Branch.

Tom

Mail Envelope Properties (3F1E7F58.680 : 0 : 20628)

Subject: CONTAINMENT SPRAY SYSTEM SURVEILLANCE LICENSE
AMENDMENT REQUEST

Creation Date: 7/23/03 8:28AM

From: Thomas Alexion

Created By: TWA@nrc.gov

Recipients	Action	Date & Time
entergy.com	Transferred	07/23/03 08:28AM
DBOYD (BOYD, DENNIS W)		

Post Office	Delivered	Route
		entergy.com

Files	Size	Date & Time
OrrRAI.wpd	3311	07/22/03 11:41AM
MESSAGE	700	07/23/03 08:28AM

Options

Auto Delete:	No
Expiration Date:	None
Notify Recipients:	Yes
Priority:	Standard
Reply Requested:	No
Return Notification:	None

Concealed Subject:	No
Security:	Standard

To Be Delivered:	Immediate
Status Tracking:	Delivered & Opened

REVISED REQUEST FOR ADDITIONAL INFORMATION
REACTOR SYSTEMS BRANCH
CONTAINMENT SPRAY SYSTEM SURVEILLANCES
ARKANSAS NUCLEAR ONE, UNIT 2

On May 1, 2003, the licensee submitted a request for a license amendment to Surveillance Requirement (SR) 4.6.2.1. The proposed changes would delete the requirement to verify the position of valves that are locked, sealed, or otherwise secured in their correct position, and replace the quantitative allowable pump degradation value with a requirement to verify the pumps perform in accordance with the Inservice Testing Program.

In Section 4.0, Technical Analysis, the licensee says that SR 4.6.2.1.a.1 would be modified to exclude the requirement to verify the position of locked, sealed or secured valves in their correct position.

Provide or justify the removal of verifying system alignment such that should the need for the recirculation cooling mode arise, that the alignment of valves can be made to provide recirculation without unlocking, unsealing, or unsecuring valves that would be excluded in the modified SR.