

Exelon Generation Company, LLC
LaSalle County Station
2601 North 21st Road
Marseilles, IL 61341-9757

www.exeloncorp.com

Nuclear

August 4, 2003

10 CFR 50.73

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

LaSalle County Station, Units 1 and 2
Facility Operating License Nos. NPF-11 and NPF-18
NRC Docket Nos. 50-373 and 50-374

Subject: Retraction of Licensee Event Report

Exelon Generation Company, (EGC), LLC, is retracting Licensee Event Report Number 02-001-00, Docket No. 050-373. Structural analyses have been completed that demonstrate that the subject divisional area coolers were operable with the cooling coil mounting screws not installed.

This event was therefore not reportable under 10 CFR 50.73(a)(2)(v)(D) and (a)(2)(ii)(B).

Should you have any questions concerning this letter, please contact Mr. Glen Kaegi, Regulatory Assurance Manager, at (815) 415-2800.

Respectfully,



Susan R. Landahl
Plant Manager
LaSalle County Station

cc: Regional Administrator - NRC Region III
NRC Senior Resident Inspector - LaSalle County Station

JE22