

September 9, 2003

MEMORANDUM TO: Stephen Dembek, Chief, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

FROM: Alan B. Wang, Project Manager, Section 2 **/RA/**
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: SUMMARY OF MEETING WITH THE BOILING WATER REACTOR
OWNERS GROUP (BWROG) CONCERNING THE DEVELOPMENT OF
A NEW REACTOR CORE STABILITY LIMIT

On August 15, 2003, an open meeting was held between the BWROG and the NRC staff to discuss the BWROG efforts to develop a new reactor core stability limit. The new stability limit was to provide the best basis for the final resolution of this issue with the class of boiling water reactors (BWR) referred to as the "detect and suppress" (D&S) plants. In June 2001, GE Nuclear Energy (GENE) reported that generic delta I versus oscillation magnitude (DIVOM) curves could be non-conservative. This resulted in a 10 CFR Part 21 notification. Individual plants implemented corrective actions as a result and the BWROG D&S Committee was formed to develop a new generic DIVOM correlation.

Mike May opened the meeting with a short description of the Nine Mile Point 2 instability event. His main point was that Nine Mile had an instability event and the operating power range monitor (OPRM) scrambled the reactor as designed. The staff had several questions including: (1) where was the plant in the power flow map, (2) what would have happened at a plant without an operable OPRM, and (3) were the oscillations core wide or regional? Mr. May noted that the licensee is still analyzing the event and these questions need to be answered at a later meeting.

Mr. May provided a background of the stability effort. He noted that based on several considerations, the BWROG has decided that the best alternative is development of plant-specific DIVOM curves. Mr. Wermiel of the NRC staff noted that this has always been an option to the industry. He stated that a response to the Part 21 notification still needed to be made. In addition, he wanted a letter from the BWROG providing a plan from industry to resolve this issue. Mr. May noted that the BWROG can only make recommendations to its members. He noted that the BWROG needs to digest what was said today to determine their next actions, but he understands what Mr. Wermiel is looking for. He agreed to let the NRC staff know their course of action within 2 weeks. Mr. Wermiel stated that this issue has been unresolved too long and agrees that a resolution finally looks in hand.

S. Dembek

-2-

The staff thanked the BWROG for the presentation. This meeting was informational. No regulatory decisions were made. An attendance list is attached. The meeting handouts can be found in ADAMS under Accession No. ML032330211.

Project No. 691

Attachment: Meeting Attendees

cc w/att: See next page

The staff thanked the BWROG for the presentation. This meeting was informational. No regulatory decisions were made. An attendance list is attached. The meeting handouts can be found in ADAMS under Accession No. ML032330211.

Project No. 691

Attachment: Meeting Attendees

cc w/att: See next page

DISTRIBUTION:

PUBLIC

PDIV-2 Reading

RidsNrrDlpmLpdiv (HBerkow)

RidsNrrPMAWang

RidsNrrLAEPeyton

RidsOgcRp

RidsAcrsAcnwMailCenter

JWermiel (NRR/DSSA/SRXB)

FAkstulewicz (NRR/DSSA/SRXB)

SLu (NRR/DSSA/SRXB)

GThomas (NRR/DSSA/SRXB)

ZAbdullahi (NRR/DSSA/SRXB)

AAttard (NRR/DSSA/SRXB)

EKendrick (NRR/DSSA/SRXB)

THuang (NRR/DSSA/SRXB)

UShoop (NRR/DSSA/SRXB)

PClifford (NRR/DSSA/SRXB)

HScott (RES)

SBajorek (RES)

RGuzman (DLPM)

MLangschwager (DSSA/SRXB)

TMensha

Package No.: ML032320424

Meeting Notice No.: ML032100522

Handouts No.: ML032330211

ADAMS Accession No.: ML032320394

NRR-106

NRC-001

OFFICE	PDIV-2/PM	PDIV-2/LA	SRXB	PDIV-2/SC
NAME	AWang	EPeyton	FMAkstulewicz for JWermiel	SDembek
DATE	9/3/03	9/3/03	9/5/03	9/8/03

DOCUMENT NAME: G:\PDIV-2\bwrog\8-15-03bwrogstabilitymtingsummary.wpd

OFFICIAL RECORD COPY

MEETING WITH THE BOILING WATER REACTORS OWNERS GROUP

DEVELOPMENT OF A NEW REACTOR CORE STABILITY LIMIT

AUGUST 15, 2003

GE NUCLEAR ENERGY

D. Newkirk
R. Hill
I. Nir

OTHER

D. Raleigh (LIS, Scientech)
B. Gitnick (ISL)
K. Putnam (Chairman, BWROG)
J. Head (Entergy)
B. Myers (Detroit Edison)
M. May (Exelon)
D. Pruitt (Framatome)
S. Bier (PSE&G)
B. Harris (Westinghouse)
J. Fisher (Energy Northwest)

NRC

J. Wermiel
F. Akstulewicz
S. Dembek
A. Wang
S. Lu
G. Thomas
Z. Abdullahi
A. Attard
E. Kendrick
T. Huang
U. Shoop
P. Clifford
H. Scott
S. Bajorek
M. Langschwager
R. Guzman

cc:

Mr. Joseph E. Conen
Vice Chairman, BWR Owners Group
DTE Energy – Fermi 2
200 TAC
6400 N. Dixie Highway
Newport, MI 48166

Mr. J. A. Gray, Jr.
Regulatory Response Group Chairman
BWR Owners Group
Entergy Nuclear Northeast
440 Hamilton Avenue Mail Stop 12C
White Plains, NY 10601-5029

Mr. H. Lewis Sumner
Southern Nuclear Company
40 Inverness Center Parkway
P.O. Box 1295
Birmingham, AL 35242

Mr. Carl D. Terry
Vice President, Nuclear Engineering
Nine Mile Point - Station
OPS Building/2nd Floor
P.O. Box 63
Lycoming, NY 13093

Mr. Thomas G. Hurst
GE Nuclear Energy
M/C 782
175 Curtner Avenue
San Jose, CA 95125

Mr. Thomas A. Green
GE Nuclear Energy
M/C 782
175 Curtner Avenue
San Jose, CA 95125

Mr. James Meister
Exelon
Cornerstone II at Cantera
4300 Winfield Road
Warrenville, IL 60555

Mr. William A. Eaton
ENTERGY
Grand Gulf Nuclear Station
P.O. Box 756
Port Gibson, MS 39150

Mr. Mark Reddeman
Vice President Engineering
Point Beach Nuclear Plant
6610 Nuclear Road
Two Rivers, WI 54241

Mr. Richard Libra
DTE Energy
Fermi 2
M/C 280 OBA
6400 North Dixie Highway
Newport, MI 48166

Mr. James F. Klapproth
GE Nuclear Energy
M/C 706
175 Curtner Avenue
San Jose, CA 95125

Mr. Kenneth Putnam, Chairman
BWR Owners Group
Nuclear Management Company
Duane Arnold Energy Center
3277 DAEC Road
Palo, IA 52324