

# **ENERGY NORTHWEST**

P.O. Box 968 ■ Richland, Washington 99352-0968

August 11, 2003  
GO2-03-126


U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555-0001

Subject: **COLUMBIA GENERATING STATION, DOCKET NO. 50-397  
MONTHLY OPERATING REPORT  
JULY 2003**

Dear Sir or Madam:

Transmitted herewith is the Monthly Operating Report for the month of July 2003 as required by Technical Specification 5.6.4.

Respectfully,



WS Oxenford  
Plant General Manager  
Mail Drop 927M

Attachment

cc: TP Gwynn - NRC RIV  
BJ Benney - NRC NRR  
NRC Senior Resident Inspector - 988C  
TC Poindexter - Winston & Strawn  
INPO  
ANI Library  
Utility Data Institute  
RN Sherman - BPA / 1399

IE24

**OPERATING STATUS REPORT**  
**for Columbia Generating Station**

Date: August 1, 2003

---

1. Docket: 50-397
2. Reporting Period: July 2003
3. Utility Contact: Patricia Campbell (509) 377-4664
4. Design Electrical Rating (Net MW<sub>e</sub>): 1153
5. Maximum Dependable Capacity - summer (Net MW<sub>e</sub>): 1107

	MONTH	YEAR	CUMULATIVE
6. Hours Reactor Critical	711.4	3,490.0	123,185.5
7. Hours Generator On-Line	688.7	3,369.1	119,740.6
8. Unit Reserve Shutdown Hours	0.0	0.0	3,274.7
9. Net Electrical Energy (MWH)	666,947	3,543,719	118,796,498

---

## UNIT SHUTDOWNS

DOCKET NO.: 50-397  
 UNIT NAME: Columbia Generating Station  
 DATE: August 1, 2003  
 COMPLETED BY: P. Campbell  
 TELEPHONE: (509) 377-4664

REPORT PERIOD: July, 2003

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause / Corrective Actions  Comments
03-004	6/30/03	F	55.3	A	4	Forced outage due to a turbine trip caused by a main transformer fault that occurred on June 30, and ended July 3.

**SUMMARY:** The plant began the month in a Forced Outage that ended on July 3rd. The plant ended the month at 100% power.

### (1) REASON

A - Equipment Failure  
 B - Maintenance or Test  
 C - Refueling  
 D - Regulatory Restriction

E - Operator Training &  
 License Examination  
 F - Administration  
 G - Operational Error  
 H - Other

### (2) METHOD

1 - Manual  
 2 - Manual Trip/Scram  
 3 - Auto Trip/Scram  
 4 - Continuation  
 5 - Other (Explain)