

September 11, 2003

MEMORANDUM TO: Laura Dudes, Section Chief  
New Reactors Section  
New, Research and Test Reactors Program  
Division of Regulatory Improvement Programs, NRR

FROM: Joseph Colaccino, Senior Project Manager */RA/*  
New Reactors Section  
New, Research and Test Reactors Program  
Division of Regulatory Improvement Programs, NRR

SUBJECT: JUNE 5, 2003, AP1000 TELEPHONE CONFERENCE CALL SUMMARY

On Thursday, June 5, 2003, a telephone conference call was held with Westinghouse Electric Company (Westinghouse) representatives and Nuclear Regulatory Commission (NRC) staff to discuss the information contained in the AP1000 design control document (DCD) Tier 2 Section 3.11, Environmental Qualification of Mechanical and Electrical Equipment. The call participants are listed in Attachment 1. A summary of the conference call is included below.

The staff noted that the equipment qualification design curves were not included in DCD Tier 2 Chapter 3. Westinghouse noted that this information was included in composite curves in DCD Tier 2 Chapter 6. The NRC staff stated that they saw potential problems with individual curves not included in the DCD. After some discussion, Westinghouse agreed to insert the design curves in curves in DCD Tier 2 Chapter 3 .

Subsequent to this phone call, the NRC staff verified that these changes were included in Revision 6 of the DCD.

Docket No. 52-006

Attachment: As stated

cc w/att: See next page

September 11, 2003

MEMORANDUM TO: Laura Dudes, Section Chief  
New Reactors Section  
New, Research and Test Reactors Program  
Division of Regulatory Improvement Programs, NRR

FROM: Joseph Colaccino, Senior Project Manager /RA/  
New Reactors Section  
New, Research and Test Reactors Program  
Division of Regulatory Improvement Programs, NRR

SUBJECT: JUNE 5, 2003, AP1000 TELEPHONE CONFERENCE CALL SUMMARY

On Thursday, June 5, 2003, a telephone conference call was held with Westinghouse Electric Company (Westinghouse) representatives and Nuclear Regulatory Commission (NRC) staff to discuss the information contained in the AP1000 design control document (DCD) Tier 2 Section 3.11, Environmental Qualification of Mechanical and Electrical Equipment. The call participants are listed in Attachment 1. A summary of the conference call is included below.

The staff noted that the equipment qualification design curves were not included in DCD Tier 2 Chapter 3. Westinghouse noted that this information was included in composite curves in DCD Tier 2 Chapter 6. The NRC staff stated that they saw potential problems with individual curves not included in the DCD. After some discussion, Westinghouse agreed to insert the design curves in curves in DCD Tier 2 Chapter 3 .

Subsequent to this phone call, the NRC staff verified that these changes were included in Revision 6 of the DCD.

Docket No. 52-006

Attachment: As stated

cc w/att: See next page

Distribution:

Hard Copy

RNRP R/F

JLyons

JSegala

JStarefos

E-mail

RWeisman, OGC

PUBLIC

DMatthews

JMoore, OGC

ACCESSION NUMBER: ML032340057\*See previous concurrence

|        |            |          |         |
|--------|------------|----------|---------|
| OFFICE | RNRP/PM    | EPHP/SC* | RNRP/SC |
| NAME   | JColaccino | HWalker  | LDudes  |
| DATE   | 9/2/03     | 9/2/03   | 9/11/03 |

OFFICIAL RECORD COPY

JUNE 6 2003  
TELEPHONE CONFERENCE CALL SUMMARY  
LIST OF PARTICIPANTS

Nuclear Regulatory Commission

H. Walker  
J. Colaccino

Westinghouse

M. Corletti

AP 1000

cc:

Mr. W. Edward Cummins  
AP600 and AP1000 Projects  
Westinghouse Electric Company  
P.O. Box 355  
Pittsburgh, PA 15230-0355

Mr. H. A. Sepp  
Westinghouse Electric Company  
P.O. Box 355  
Pittsburgh, PA 15230

Lynn Connor  
Doc-Search Associates  
2211 SW 1<sup>ST</sup> Ave - #1502  
Portland, OR 97201

Barton Z. Cowan, Esq.  
Eckert Seamans Cherin & Mellott, LLC  
600 Grant Street 44<sup>th</sup> Floor  
Pittsburgh, PA 15219

Mr. Ed Rodwell, Manager  
Advanced Nuclear Plants' Systems  
Electric Power Research Institute  
3412 Hillview Avenue  
Palo Alto, CA 94304-1395

Charles Brinkman, Director  
Washington Operations  
Westinghouse Electric Company  
12300 Twinbrook Parkway, Suite 330  
Rockville, MD 20852

Mr. R. Simard  
Nuclear Energy Institute  
1776 I Street NW  
Suite 400  
Washington, DC 20006

Mr. Thomas P. Miller  
U.S. Department of Energy  
Headquarters - Germantown  
19901 Germantown Road  
Germantown, MD 20874-1290

Mr. David Lochbaum  
Nuclear Safety Engineer  
Union of Concerned Scientists  
1707 H Street NW, Suite 600  
Washington, DC 20006-3919

Mr. Paul Gunter  
Nuclear Information & Resource Service  
1424 16th Street, NW., Suite 404  
Washington, DC 20036

Mr. Tom Clements  
6703 Guide Avenue  
Takoma Park, MD 20912

Mr. James Riccio  
Greenpeace  
702 H Street, NW, Suite 300  
Washington, DC 20001

Mr. James F. Mallay, Director  
Regulatory Affairs  
FRAMATOME, ANP  
3315 Old Forest Road  
Lynchburg, VA 24501

Mr. Ed Wallace, General Manager  
Projects  
PBMR Pty LTD  
PO Box 9396  
Centurion 0046  
Republic of South Africa

Mr. Vince Langman  
Licensing Manager  
Atomic Energy of Canada Limited  
2251 Speakman Drive  
Mississauga, Ontario  
Canada L5K 1B2

Mr. Gary Wright, Manager  
Office of Nuclear Facility Safety  
Illinois Department of Nuclear Safety  
1035 Outer Park Drive  
Springfield, IL 62704

Dr. Gail H. Marcus  
U.S. Department of Energy  
Room 5A-143  
1000 Independence Ave., SW  
Washington, DC 20585

Mr. Paul Leventhal  
Nuclear Control Institute  
1000 Connecticut Avenue, NW  
Suite 410  
Washington, DC 20036

Mr. Jack W. Roe  
SCIENTECH, INC.  
910 Clopper Road  
Gaithersburg, MD 20878

Patricia Campbell  
Winston & Strawn  
1400 L Street, NW  
Washington, DC 20005

Mr. David Ritter  
Research Associate on Nuclear Energy  
Public Citizens Critical Mass Energy  
and Environmental Program  
215 Pennsylvania Avenue, SE  
Washington, DC 20003

Mr. Michael M. Corletti  
Passive Plant Projects & Development  
AP600 & AP1000 Projects  
Westinghouse Electric Company  
P. O. Box 355  
Pittsburgh, PA 15230-0355