

The analytical methods used to determine the core operating limits identified above shall be those previously reviewed and approved by the NRC, and identified below. The COLR will contain the complete identification for each of the TS referenced topical reports used to prepare the COLR (i.e., report number, title, revision, date, and any supplements). The core operating limits shall be determined so that applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met. The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided for information for each reload cycle to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

REFERENCES

1. VEP-FRD-42-A, "Reload Nuclear Design Methodology"
- 2a. WCAP-9220-P-A, "Westinghouse ECCS Evaluation Model - 1981 Version," (W Proprietary)
- 2b. WCAP-9561-P-A, "BART A-1: A Computer Code for the Best Estimate Analysis of Reflood Transients-Special Report: Thimble Modeling in W ECCS Evaluation Model," (W Proprietary)
- 2c. WCAP-10266-P-A, "The 1981 Version of the Westinghouse ECCS Evaluation Model Using the BASH Code," (W Proprietary)
- 2d. WCAP-10054-P-A, "Westinghouse Small Break ECCS Evaluation Model Using the NOTRUMP Code," (W Proprietary)
- 2e. WCAP-10079-P-A, "NOTRUMP, A Nodal Transient Small Break and General Network Code," (W Proprietary)
- 2f. WCAP-12610-P-A, "VANTAGE+ Fuel Assembly Report," (Westinghouse Proprietary)
- 3a. VEP-NE-2-A, "Statistical DNBR Evaluation Methodology"
- 3b. VEP-NE-3-A, "Qualification of the WRB-1 CHF Correlation in the Virginia Power COBRA Code"