

EMERGENCY CORE COOLING SYSTEMS

ECCS SUBSYSTEMS - $T_{avg} \geq 280^{\circ}\text{F}$

LIMITING CONDITION FOR OPERATION

3.5.2 Two independent ECCS subsystems shall be OPERABLE with each subsystem comprised of:

- a. One OPERABLE high pressure injection (HPI) pump, *
- b. One OPERABLE low pressure injection (LPI) pump,
- c. One OPERABLE decay heat cooler, and
- d. An OPERABLE flow path capable of taking suction from the borated water storage tank (BWST) on a safety injection signal and manually transferring suction to the containment sump during the recirculation phase of operation.

| APPLICABILITY: MODES 1, 2 and 3 *.

ACTION:

- a. With one HPI train inoperable, restore the inoperable HPI train to OPERABLE status within 72 hours or be in HOT SHUTDOWN within the next 12 hours.
- b. With one LPI train or its associated decay heat cooler inoperable, restore the inoperable equipment to OPERABLE status within 7 days or be in HOT SHUTDOWN within the next 12 hours.
- c. In the event the ECCS is actuated and injects water into the Reactor Coolant System, a Special Report shall be prepared and submitted to the Commission pursuant to Specification 6.9.2 within 90 days describing the circumstances of the actuation and the total accumulated actuation cycles to date.

SURVEILLANCE REQUIREMENTS

4.5.2 Each ECCS subsystem shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying that each valve (manual, power operated or automatic) in the flow path that is not locked, sealed or otherwise secured in position, is in its correct position.

| * *An exception applies to the HPI pumps for the purpose of conducting Restart Test Plan inspection activities. This exception is valid during the ongoing Thirteenth Refueling Outage for entries into MODE 3 from MODE 4. Under this exception, neither HPI train is required to be capable of taking suction from the LPI trains when aligned for containment sump recirculation. The HPI trains will otherwise be OPERABLE. Operation in MODE 1 or MODE 2 while relying upon the provisions of this exception is prohibited.*