



**FPL**

Florida Power & Light Company, 6501 S. Ocean Drive, Jensen Beach, FL 34957

September 10, 2003

L-2003-227  
10 CFR 50.46

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555

Re: St. Lucie Unit 2  
Docket No. 50-389  
LBLOCA Evaluation Model  
30-Day 10 CFR 50.46 Report

Westinghouse Electric (W) is the current fuel vendor for St. Lucie Unit 2, and performs the calculations to demonstrate that the Unit 2 emergency core cooling system (ECCS) performance conforms to 10 CFR 50.46. W employs an acceptable evaluation model consistent with 10 CFR 50, Appendix K. Model changes/errors in the large break loss-of-coolant accident (LBLOCA) analysis has resulted in a significant change to the calculated peak cladding temperature (PCT), and is hereby reported pursuant to 10 CFR 50.46(a)(3)(ii). The small break loss-of-coolant accident (SBLOCA) analysis PCT remains unchanged from that reported in FPL letter L-2002-196 dated October 15, 2002.

Please contact George Madden at 772-467-7155 if you have any questions regarding this matter.

Very truly yours,

William Jefferson, Jr.  
Vice President  
St. Lucie Plant

WJ/spt

Attachment

A001

**St. Lucie Unit 2 10 CFR 50.46 LBLOCA 30-Day Report**

Westinghouse Electric (W) is the current fuel vendor for St. Lucie Unit 2, and performs the calculations to demonstrate that the Unit 2 emergency core cooling system (ECCS) performance conforms to 10 CFR 50.46. W employs an acceptable evaluation model consistent with 10 CFR 50, Appendix K. Model changes/errors in the large break loss-of-coolant accident (LBLOCA) analysis have resulted in a significant change to the calculated peak cladding temperature (PCT), and is hereby reported pursuant to 10 CFR 50.46(a)(3)(ii). The small break loss-of-coolant accident (SBLOCA) analysis PCT remains unchanged from that reported in Reference 1.

**Nature of the Model Changes and Corrective Action**

**Error in the Locked-Rotor K-Factor Value**

**Description of Deviation**

The St. Lucie Unit 2 ECCS performance analyses PCTs applicable to the current operating cycle (Cycle 14) were previously reported in References 1 and 2.

A review of the LBLOCA analysis revealed that the reactor coolant pump locked rotor k-factor used in the analysis was incorrect. The locked-rotor k-factor using the as-built reactor coolant pump test data was found to be approximately 25% greater than the value currently used. The k-factor value was corrected and the impact of the k-factor error on the limiting break was estimated using the updated evaluation model, 1999 EM (Reference 3). This evaluation model (1999 EM) was approved by the NRC in Reference 4 for application to CE PWRs.

**Impact of the Code Error**

The impact of the model change (1999 EM) on the LBLOCA analysis is estimated to be a reduction in the PCT of 140°F. The impact of the k-factor error on the LBLOCA PCT is estimated to be an increase of 110°F.

The cumulative change of the PCT changes becomes 266°F as provided in the table below. The final LBLOCA PCT becomes 2136°F.

**References**

1. FPL Letter L-2002-196, St. Lucie Unit 2, Docket No. 50-389, Proposed License Amendment - Reduce the Minimum Reactor Coolant System Flow, dated October 15, 2002.

**St. Lucie Unit 2 10 CFR 50.46 LBLOCA 30-Day Report**

2. FPL Letter L-2003-078, St. Lucie Units 1 and 2, Docket Nos. 50-335 and 50-389, Acceptance Criteria for Emergency Core Cooling Systems for Light Water Nuclear Power Reactors: 10 CFR 50.46 Annual Report, dated March 26, 2003.
3. CENPD-132, Supplement 4-P-A, *Calculative Methods for the CE Nuclear Power Large Break LOCA Evaluation Model*, dated March 2001.
4. NRC Letter, S. A. Richards (NRC) to P. W. Richardson (Westinghouse), Safety Evaluation of Topical Report CENPD-132, Supplement 4, Revision 1, *Calculative Methods for the CE Nuclear Power Large Break LOCA Evaluation Model*, dated December 15, 2000.

Unit 2 LBLOCA Summary	PCT
Current evaluation model calculated LBLOCA PCT	2150°F
Estimated impact of STRIKIN-II errors (previously reported in L-2003-078)	1°F
Estimated impact of RCS flow reduction from 363,000 gpm to 355,000 gpm (previously reported in L-2002-196)	15°F
Estimated impact due to model change from 1985 EM to 1999 EM	-140°F
Estimated impact of locked-rotor k-factor error	110°F
Cumulative Change	266°F
Total PCT Change	-14°F
Final LBLOCA PCT	2136°F