

### 3.8 ELECTRICAL POWER SYSTEMS

#### 3.8.3 Diesel Fuel Oil, Lube Oil, and Starting Air

**LCO 3.8.3**      The stored diesel fuel oil, lube oil, and starting air subsystem shall be within limits for each required diesel generator (DG).

**APPLICABILITY:**      When associated DG is required to be OPERABLE.

#### ACTIONS

----- **NOTE** -----  
Separate Condition entry is allowed for each DG.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more DGs with fuel level < 80,400 gal and > 69,300 gal in storage tank.	A.1      Restore fuel oil level to within limits.	48 hours
B. One or more DGs with lube oil inventory < 750 gal and > 686 gal.	B.1      Restore lube oil inventory to within limits.	48 hours
C. One or more DGs with stored fuel oil total particulates not within limit.	C.1      Restore fuel oil total particulates within limit.	7 days
D. One or more DGs with new fuel oil properties not within limits.	D.1      Restore stored fuel oil properties to within limits.	30 days

(continued)