



Entergy Operations, Inc.
River Bend Station
5485 U.S. Highway 61
P. O. Box 220
St. Francisville, LA 70775
Tel 225 336 6225
Fax 225 635 5068

Rick J. King
Director
Nuclear Safety Assurance

September 11, 2003

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Operating Report
River Bend Station Unit 1
Docket No. 50-458
License No. NPF-47

File No.: G9.5, G4.25

RBG-46172
RBF1-03-0170

Ladies and Gentlemen:

In accordance with River Bend Station Technical Specification 5.6.4, enclosed is the Monthly Operating Report for August 2003.

Sincerely,

A handwritten signature in black ink, appearing to read "Rick J. King".

RJK/dhw
enclosure

IE24

Monthly Operating Report
September 11, 2003
RBG-46172
RBF1-03-0170
Page 2 of 2

cc: U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

NRC Senior Resident Inspector
R-SB-14

INPO Records Center
700 Galleria Parkway
Atlanta, GA 30339-3064

Mr. Jim Calloway
Public Utility Commission of Texas
1701 N. Congress Ave.
Austin, TX 78711-3326

Dottie Sherman
American Nuclear Insurers
29 South Main Street
West Hartford, CT 06107

Docket No. 50/458
River Bend Station

Date: September 11, 2003
Completed by: Danny H. Williamson
Title: Sr. Licensing Specialist
Telephone: 225-381-4279

Page 1 of 2

OPERATING STATUS

1. Reporting period: August 2003
2. Maximum dependable capacity (MWe-Net): 966
3. Design electrical rating (MWe-Net): 966

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
4. Number of hours reactor was critical	<u>744.0</u>	<u>5215.5</u>	<u>125,223.7</u>
5. Hours generator on line	<u>744.0</u>	<u>5158.4</u>	<u>121,503.8</u>
6. Unit reserve shutdown hours	<u>0</u>	<u>0</u>	<u>0</u>
7. Net electrical energy generated (MWH)	<u>726,654</u>	<u>4,834,155</u>	<u>108,899,531</u>

UNIT SHUTDOWNS

<u>NUMBER</u>	<u>DATE</u>	<u>TYPE</u>	<u>DURATION</u>	<u>SHUTDOWN METHOD</u>	<u>REASON</u>	<u>CAUSE / CORRECTIVE ACTIONS</u>
(none)						

LEGEND:**TYPE:**


F - Forced
S - Scheduled

SHUTDOWN METHOD:

1 - Manual
2 - Manual trip / scram
3 - Automatic trip / scram
4 - Continuation
5 - Other (explain)

REASON:

A - Equipment failure (explain)
B - Maintenance or Test
C - Refuelling
D - Regulatory restriction
E - Operator training / License Exam
F - Administrative
G - Operational error (explain)
H - Other (explain)



Danny H. Williamson