

SEP 15 2003

LR-N03-0393



U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Gentlemen:

**MONTHLY OPERATING REPORT
SALEM GENERATING STATION UNIT 1
DOCKET NO. 50-272**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 1 Technical Specifications, the operating statistics for August 2003 are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "C. Fricker", written over a horizontal line.

Carl J. Fricker
Operations Director

Attachments

C Distribution

IE22

DOCKET NO.: 50-272
 UNIT: Salem 1
 DATE: 9/9/03
 COMPLETED BY: F. Todd
 TELEPHONE: (856) 339-1316

Reporting Period August 2003

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)
 Maximum Dependable Capacity (MWe-Net)

No. of hours reactor was critical
 No. of hours generator was on line (service hours)
 Unit reserve shutdown hours
 Net Electrical Energy (MWH)

1130		
1096		
Month	Year-to-date	Cumulative
732	5761	147949
686	5714	143265
0	0	0
747523	6211583	146115549

UNIT SHUTDOWNS

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT
1	8/1/03 - 8/3/03	F	58 hrs.	A	4	500kv 1-5 Breaker Failure

(1) Reason

A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training/License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other

(2) Method

1 - Manual
 2 - Manual Trip/Scram
 3 - Automatic Trip/Scram
 4 - Continuation
 5 - Other (Explain)

DOCKET NO.: 50-272
UNIT: Salem 1
DATE: 9/9/03
COMPLETED BY: R. Ritzman
TELEPHONE: (856) 339-1445

Summary Of Monthly Operating Experience

- Salem 1 was offline at the beginning of the month.
- The unit was placed online on August 3, reaching 100% reactor power on August 4.
- At the end of the month, Salem 1 completed 28 days of continuous on-line operation.