



MICHAEL S. TUCKMAN
Executive Vice President
Nuclear Generation

Duke Power
P.O. Box 1006
Charlotte, NC 28201-1006

Mailing Address:
526 South Church Street
Charlotte, NC 28202

704 382 2200
704 382 4360 fax

September 15, 2003

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Subject: Duke Energy Corporation
Oconee Nuclear Station, Docket Nos. 50-269, -270, -287
McGuire Nuclear Station, Docket Nos. 50-369, -370
Catawba Nuclear Station, Docket Nos. 50-413, -414
Monthly Performance and Operation Status - June, 2003

Please find attached information concerning the performance and operation status of the Oconee, McGuire and Catawba Nuclear Stations for the month of August, 2003.

Any questions or comments may be directed to Roger A. Williams at (704) 382-5346.

Sincerely,

M. S. Tuckman

M. S. Tuckman

JE24

Page 2

**U.S. Nuclear Regulatory Commission
Monthly Performance and Operation Status
September 15, 2003**

xc: L. A. Reyes, Regional Administrator
U.S. Nuclear Regulatory Commission
Sam Nunn Atlanta Federal Center
61 Forsythe Street, SW, Suite 23T85
Atlanta, GA 30303-8931

R. E. Martin, Senior Project Manager
U.S. Nuclear Regulatory Commission
Mail Stop O-8 H12
Washington, DC 20555

L. N. Olshan, Senior Project Manager
U.S. Nuclear Regulatory Commission
Mail Stop O-8 H12
Washington, DC 20555

Ms. Margaret Aucoin
Nuclear Assurance Corporation
3930 E. Jones Bridge Road #300
Norcross, GA 30092-2107

INPO Records Center
700 Galleria Parkway
Atlanta, GA 30339-5957

Dottie Sherman, ANI Library
American Nuclear Insurers
Town Center, Suite 300S
29 South Main Street
West Hartford, CT 06107-2445

M. Shannon, Senior Resident Inspector, Oconee Nuclear Station
J. Brady, Senior Resident Inspector, McGuire Nuclear Station
E. Guthrie, Senior Resident Inspector, Catawba Nuclear Station

Operating Data Report

| | |
|--------------|---------------------------|
| Docket No. | <u>50-269</u> |
| Date | <u>September 15, 2003</u> |
| Completed By | <u>Roger Williams</u> |
| Telephone | <u>704-382-5346</u> |

Operating Status

1. Unit Name: Oconee 1
2. Reporting Period: August 1, 2003 - August 31, 2003
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

| | This Month | YTD | Cumulative |
|---|------------|----------|------------|
| 11. Hours in Reporting Period | 744.0 | 5831.0 | 264096.0 |
| 12. Number of Hours Reactor was Critical | 744.0 | 5831.0 | 209394.1 |
| 13. Reactor Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 14. Hours Generator On-Line | 744.0 | 5831.0 | 205891.1 |
| 15. Unit Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 16. Gross Thermal Energy Generated (MWH) | 1842797 | 14811404 | 510014058 |
| 17. Gross Electrical Energy Generated (MWH) | 638163 | 5192728 | 176444035 |
| 18. Net Electrical Energy Generated (MWH) | 608610 | 4972715 | 167846761 |
| 19. Unit Service Factor | 100.0 | 100.0 | 78.0 |
| 20. Unit Availability Factor | 100.0 | 100.0 | 78.0 |
| 21. Unit Capacity Factor (Using MDC Net) | 96.7 | 100.8 | 74.5 |
| 22. Unit Capacity Factor (Using DER Net) | 92.3 | 96.3 | 71.7 |
| 23. Unit Forced Outage Rate | 0.0 | 0.0 | 9.0 |
| 24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each) | | | |

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

| | Forecast | Achieved |
|----------------------|----------|----------|
| Initial Criticality | _____ | _____ |
| Initial Electricity | _____ | _____ |
| Commercial Operation | _____ | _____ |

NRC Calculated from Generator Nameplate Data:
 1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-269UNIT NAME: Oconee 1DATE: September 15, 2003COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: August, 2003

| No. | Date: | Type F - Forced S - Scheduled | Duration Hours | (1) Reason | (2) Method of Shutdown R/X | Licensed Event Report No. | Cause and Corrective Action to Prevent Recurrence |
|----------|-------|-------------------------------------|-------------------|------------|-------------------------------|---------------------------------|---|
| | | | No | Outages | for the Month | | |
| Summary: | | | | | | | |

(1) Reason

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

(2) Method

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 1
2. Scheduled next refueling shutdown: September 2003
3. Scheduled restart following refueling: December 2003

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies (a) in the core: 177
 (b) in the spent fuel pool: 878*
 (c) in the ISFSI: 1848****
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present capacity: January 2005***

DUKE POWER COMPANY

DATE: September 15, 2003

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

* Represents the combined total for Units 1 and 2

** On March 29, 1990, received a site specific license for ISFSI which will store 2112 assemblies (88 modules). Forty (40) site specific modules were constructed and loaded.

*** In 1999 Oconee transitioned to its general license. Forty-four (44) general license modules were installed and 30 modules have now been loaded.
Additional modules will be installed on an as-needed basis.

**** Represents the combined total for Units 1, 2, and 3

Operating Data Report

| | |
|--------------|--------------------|
| Docket No. | 50-270 |
| Date | September 15, 2003 |
| Completed By | Roger Williams |
| Telephone | 704-382-5346 |

Operating Status

1. Unit Name: Oconee 2
2. Reporting Period: August 1, 2003 - August 31, 2003
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net Mwe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity(Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

| | This Month | YTD | Cumulative |
|---|------------|----------|------------|
| 11. Hours in Reporting Period | 744.0 | 5831.0 | 254016.0 |
| 12. Number of Hours Reactor was Critical | 744.0 | 5831.0 | 206916.8 |
| 13. Reactor Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 14. Hours Generator On-Line | 744.0 | 5831.0 | 204337.7 |
| 15. Unit Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 16. Gross Thermal Energy Generated (MWH) | 1911208 | 14963017 | 505516572 |
| 17. Gross Electrical Energy Generated (MWH) | 666839 | 5264701 | 173917685 |
| 18. Net Electrical Energy Generated (MWH) | 637763 | 5048717 | 165775035 |
| 19. Unit Service Factor | 100.0 | 100.0 | 80.4 |
| 20. Unit Availability Factor | 100.0 | 100.0 | 80.4 |
| 21. Unit Capacity Factor (Using MDC Net) | 101.3 | 102.3 | 76.5 |
| 22. Unit Capacity Factor (Using DER Net) | 96.8 | 97.7 | 73.7 |
| 23. Unit Forced Outage Rate | 0.0 | 0.0 | 8.4 |
| 24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each) | | | |

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

| | Forecast | Achieved |
|----------------------|----------|----------|
| Initial Criticality | _____ | _____ |
| Initial Electricity | _____ | _____ |
| Commercial Operation | _____ | _____ |

NRC Calculated from Generator Nameplate Data:
 1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-270

UNIT NAME: Oconee 2

DATE: September 15, 2003

COMPLETED BY: Roger Williams

TELEPHONE: 704-382-5346

REPORT MONTH: August, 2003

| No. | Date: | Type F - Forced S - Scheduled | Duration Hours | (1) Reason | (2) Method of Shutdown R/X | Licensed Event Report No. | Cause and Corrective Action to Prevent Recurrence |
|-----|-------|-------------------------------------|-------------------|------------|-------------------------------|---------------------------------|---|
| | | | No | Outages | for the Month | | |

Summary:

(1) Reason

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

(2) Method

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 2
2. Scheduled next refueling shutdown: March, 2004
3. Scheduled restart following refueling: June, 2004

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies

| | |
|-----|--------------------------------------|
| (a) | in the core: <u>177</u> |
| (b) | in the spent fuel pool: <u>878*</u> |
| (c) | in the ISFSI: <u>See unit 1 ****</u> |
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present capacity: January 2005***

DUKE POWER COMPANY

DATE: September 15, 2003

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

* Represents the combined total for Units 1 and 2

** See footnote on Unit 1

*** In 1999 Oconee transitioned to its general license. Forty-four (44) general license modules were installed and 30 modules have now been loaded.
Additional modules will be installed on an as-needed basis.

**** See footnote on Unit 1

Operating Data Report

| | |
|--------------|---------------------------|
| Docket No. | <u>50-287</u> |
| Date | <u>September 15, 2003</u> |
| Completed By | <u>Roger Williams</u> |
| Telephone | <u>704-382-5346</u> |

Operating Status

1. Unit Name: Oconee 3
2. Reporting Period: August 1, 2003 - August 31, 2003
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

| | This Month | YTD | Cumulative |
|---|------------|----------|------------|
| 11. Hours in Reporting Period | 744.0 | 5831.0 | 251663.0 |
| 12. Number of Hours Reactor was Critical | 744.0 | 4637.7 | 199690.6 |
| 13. Reactor Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 14. Hours Generator On-Line | 744.0 | 4538.9 | 196945.0 |
| 15. Unit Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 16. Gross Thermal Energy Generated (MWH) | 1910592 | 11398221 | 492657881 |
| 17. Gross Electrical Energy Generated (MWH) | 663453 | 3987275 | 170536550 |
| 18. Net Electrical Energy Generated (MWH) | 634644 | 3806578 | 162706223 |
| 19. Unit Service Factor | 100.0 | 77.8 | 78.3 |
| 20. Unit Availability Factor | 100.0 | 77.8 | 78.3 |
| 21. Unit Capacity Factor (Using MDC Net) | 100.8 | 77.2 | 75.8 |
| 22. Unit Capacity Factor (Using DER Net) | 96.3 | 73.7 | 73.0 |
| 23. Unit Forced Outage Rate | 0.0 | 9.1 | 9.0 |
| 24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each) | | | |

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

| | Forecast | Achieved |
|----------------------|----------|----------|
| Initial Criticality | _____ | _____ |
| Initial Electricity | _____ | _____ |
| Commercial Operation | _____ | _____ |

NRC Calculated from Generator Nameplate Data:
 1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-287UNIT NAME: Oconee 3DATE: September 15, 2003COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: August, 2003

| No. | Date: | Type F - Forced S - Scheduled | Duration Hours | (1) Reason | (2) Method of Shutdown R/X | Licensed Event Report No. | Cause and Corrective Action to Prevent Recurrence |
|----------|-------|-------------------------------------|-------------------|------------|-------------------------------|---------------------------------|---|
| | | | No | Outages | for the Month | | |
| Summary: | | | | | | | |

(1) Reason

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

(2) Method

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 3
2. Scheduled next refueling shutdown: October 2004
3. Scheduled restart following refueling: December 2004

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
(a) in the core: 177
(b) in the spent fuel pool: 476
(c) in the ISFSI: See Unit 1 ****
8. Present licensed fuel pool capacity: 825
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present capacity: January 2005***

DUKE POWER COMPANY

DATE: September 15, 2003

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

** See footnote of Unit 1

*** In 1999 Oconee transitioned to its general license. Forty-four (44) general license modules were installed and 30 modules have now been loaded.
Additional modules will be installed on an as-needed basis.

**** See footnote on Unit 1

OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

JULY 2003

1. Personnel Exposure -

The total station liquid release for JULY has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for JULY has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

Operating Data Report

| | |
|--------------|--------------------|
| Docket No. | 50-369 |
| Date | September 15, 2003 |
| Completed By | Roger Williams |
| Telephone | 704-382-5346 |

Operating Status

1. Unit Name: McGuire 1
2. Reporting Period: August 1, 2003 - August 31, 2003
3. Licensed Thermal Power (MWt): 3411
4. Nameplate Rating (Gross MWe): 1305 *
5. Design Electrical Rating (Net Mwe): 1180
6. Maximum Dependable Capacity (Gross MWe): 1144
7. Maximum Dependable Capacity(Net MWe): 1100
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: *Nameplate Rating (GrossMWe) calculated as 1450.000 MVA * .90 power factor per Page iii, NUREG-0020.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

| | This Month | YTD | Cumulative |
|---|------------|----------|------------|
| 11. Hours in Reporting Period | 744.0 | 5831.0 | 190655.0 |
| 12. Number of Hours Reactor was Critical | 744.0 | 5831.0 | 148856.5 |
| 13. Reactor Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 14. Hours Generator On-Line | 744.0 | 5831.0 | 147555.5 |
| 15. Unit Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 16. Gross Thermal Energy Generated (MWH) | 2520630 | 19754261 | 476659516 |
| 17. Gross Electrical Energy Generated (MWH) | 848259 | 6845263 | 164347921 |
| 18. Net Electrical Energy Generated (MWH) | 816077 | 6603021 | 157518864 |
| 19. Unit Service Factor | 100.0 | 100.0 | 77.4 |
| 20. Unit Availability Factor | 100.0 | 100.0 | 77.4 |
| 21. Unit Capacity Factor (Using MDC Net) | 99.7 | 102.9 | 72.9 |
| 22. Unit Capacity Factor (Using DER Net) | 93.0 | 96.0 | 70.0 |
| 23. Unit Forced Outage Rate | 0.0 | 0.0 | 9.0 |
| 24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each) | | | |

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

| | Forecast | Achieved |
|----------------------|----------|----------|
| Initial Criticality | _____ | _____ |
| Initial Electricity | _____ | _____ |
| Commercial Operation | _____ | _____ |

UNIT SHUTDOWNS

DOCKET NO. 50-369UNIT NAME: McGuire 1DATE: September 15, 2003COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: August, 2003

| No. | Date: | Type F - Forced S - Scheduled | Duration Hours | (1) Reason | (2) Method of Shutdown R/X | Licensed Event Report No. | Cause and Corrective Action to Prevent Recurrence |
|----------|-------|-------------------------------------|-------------------|------------|-------------------------------|---------------------------------|---|
| | | | No | Outages | for the Month | | |
| Summary: | | | | | | | |

(1) Reason

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

(2) Method

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: McGuire Unit 1
2. Scheduled next refueling shutdown: March 2004
3. Scheduled restart following refueling: April 2004

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies (a) in the core: 193
(b) in the spent fuel pool: 1011
8. Present licensed fuel pool capacity: 1463
Size of requested or planned increase: ---
9. Projected date of last refueling which can be accommodated by present license capacity:
November 2005

DUKE POWER COMPANY

DATE: September 15, 2003

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

Operating Data Report

| | |
|--------------|--------------------|
| Docket No. | 50-370 |
| Date | September 15, 2003 |
| Completed By | Roger Williams |
| Telephone | 704-382-5346 |

Operating Status

1. Unit Name: McGuire 2
2. Reporting Period: August 1, 2003 - August 31, 2003
3. Licensed Thermal Power (MWt): 3411
4. Nameplate Rating (Gross MWe): 1305 *
5. Design Electrical Rating (Net Mwe): 1180
6. Maximum Dependable Capacity (Gross MWe): 1144
7. Maximum Dependable Capacity(Net MWe): 1100
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: *Nameplate Rating (GrossMWe) calculated as 1450.000 MVA * .90 power factor per Page iii, NUREG-0020.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

| | This Month | YTD | Cumulative |
|---|------------|----------|------------|
| 11. Hours in Reporting Period | 744.0 | 5831.0 | 170951.0 |
| 12. Number of Hours Reactor was Critical | 744.0 | 5831.0 | 141617.8 |
| 13. Reactor Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 14. Hours Generator On-Line | 744.0 | 5831.0 | 140364.0 |
| 15. Unit Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 16. Gross Thermal Energy Generated (MWH) | 2535741 | 19695970 | 463884330 |
| 17. Gross Electrical Energy Generated (MWH) | 855967 | 6827743 | 161383848 |
| 18. Net Electrical Energy Generated (MWH) | 824819 | 6586086 | 154968880 |
| 19. Unit Service Factor | 100.0 | 100.0 | 82.1 |
| 20. Unit Availability Factor | 100.0 | 100.0 | 82.1 |
| 21. Unit Capacity Factor (Using MDC Net) | 100.8 | 102.7 | 80.4 |
| 22. Unit Capacity Factor (Using DER Net) | 94.0 | 95.7 | 76.8 |
| 23. Unit Forced Outage Rate | 0.0 | 0.0 | 5.3 |
| 24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each) | | | |

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

| | Forecast | Achieved |
|----------------------|----------|----------|
| Initial Criticality | _____ | _____ |
| Initial Electricity | _____ | _____ |
| Commercial Operation | _____ | _____ |

UNIT SHUTDOWNS

DOCKET NO. 50-370UNIT NAME: McGuire 2DATE: September 15, 2003COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: August, 2003

| No. | Date: | Type F - Forced S - Scheduled | Duration Hours | (1) Reason | (2) Method of Shutdown R/X | Licensed Event Report No. | Cause and Corrective Action to Prevent Recurrence |
|----------|-------|-------------------------------------|-------------------|------------|-------------------------------|---------------------------------|---|
| | | | No | Outages | for the Month | | |
| Summary: | | | | | | | |

(1) Reason

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

(2) Method

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: McGuire Unit 2
2. Scheduled next refueling shutdown: September 2003
3. Scheduled restart following refueling: October 2003

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
(a) in the core: 193
(b) in the spent fuel pool: 1061
(c) in the ISFSI: 320
8. Present licensed fuel pool capacity: 1463
Size of requested or planned increase: ---
9. Projected date of last refueling which can be accommodated by present license capacity:
June 2003

DUKE POWER COMPANY

DATE: September 15, 2003

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

McGUIRE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

JULY 2003

1. Personnel Exposure -

The total station liquid release for JULY has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for JULY has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

Operating Data Report

Docket No. 50-413
Date September 15, 2003
Completed By Roger Williams
Telephone 704-382-5346

Operating Status

- | | | |
|---|----------------------------------|--------|
| 1. Unit Name: | Catawba 1 | |
| 2. Reporting Period: | August 1, 2003 - August 31, 2003 | |
| 3. Licensed Thermal Power (MWt): | | 3411 |
| 4. Nameplate Rating (Gross MWe): | | 1305 * |
| 5. Design Electrical Rating (Net Mwe): | | 1145 |
| 6. Maximum Dependable Capacity (Gross MWe): | | 1192 |
| 7. Maximum Dependable Capacity(Net MWe): | | 1129 |
| 8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons: | | |

**Notes: *Nameplate
Rating (GrossMWe)
calculated as 1450.000
MVA * .90 power
factor per Page iii,
NUREG-0020.**

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reason for Restrictions, If any: _____

| | This Month | YTD | Cumulative |
|---|------------|----------|------------|
| 11. Hours in Reporting Period | 744.0 | 5831.0 | 159312.0 |
| 12. Number of Hours Reactor was Critical | 674.1 | 5730.7 | 132835.9 |
| 13. Reactor Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 14. Hours Generator On-Line | 674.1 | 5724.0 | 131319.6 |
| 15. Unit Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 16. Gross Thermal Energy Generated (MWH) | 2237777 | 19414180 | 434278665 |
| 17. Gross Electrical Energy Generated (MWH) | 792633 | 6935333 | 154181256 |
| 18. Net Electrical Energy Generated (MWH) | 747855 | 6577667 | 145475353 |
| 19. Unit Service Factor | 90.6 | 98.2 | 82.4 |
| 20. Unit Availability Factor | 90.6 | 98.2 | 82.4 |
| 21. Unit Capacity Factor (Using MDC Net) | 89.0 | 99.9 | 80.7 |
| 22. Unit Capacity Factor (Using DER Net) | 87.8 | 98.5 | 79.8 |
| 23. Unit Forced Outage Rate | 9.4 | 1.8 | 5.4 |
| 24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each) | | | |

25. If ShutDown At End Of Report Period, Estimated Date of Startup
26. Units in Test Status (Prior to Commercial Operation)

| | Forecast | Achieved |
|----------------------|----------|----------|
| Initial Criticality | _____ | _____ |
| Initial Electricity | _____ | _____ |
| Commercial Operation | _____ | _____ |

UNIT SHUTDOWNS

DOCKET NO. 50-413UNIT NAME: Catawba 1DATE: September 15, 2003COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: August, 2003

| No. | Date: | Type F - Forced S - Scheduled | Duration Hours | (1) Reason | (2) Method of Shutdown R/X | Licensed Event Report No. | Cause and Corrective Action to Prevent Recurrence |
|-----|----------|-------------------------------------|-------------------|------------|-------------------------------|---------------------------------|---|
| 2 | 08/29/03 | F | 69.95 | A | 3 | | AUTOMATIC TRIP WAS INITIATED DUE TO RESISTANCE TEMPERATURE DETECTOR TRIPPED BY FAILURE OF PRESSURIZER CHANNEL 2 FAILING LOW |

Summary:

Catawba unit 1 began the month of August operating at approximately 100% power. On 08/14/03 at 1130 the unit began decreasing power and held at 95% power from 1529 to 08/29/03 at 0203 to evaluate options for repair of the reactor coolant loop "1A" hot leg resistance temperature detector failure. On 08/29/03 at 0203 a automatic reactor trip was initiated due to resistance temperature detector tripped by failure of pressurizer pressure channel 2 failing low. The unit was in the outage the remainder of the month.

(1) Reason

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

(2) Method

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Catawba Unit 1
2. Scheduled next refueling shutdown: November 2003
3. Scheduled restart following refueling: December 2003

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies (a) in the core: 193
(b) in the spent fuel pool: 944
8. Present licensed fuel pool capacity: 1418
Size of requested or planned increase: ---
9. Projected date of last refueling which can be accommodated by present license capacity:
November 2009

DUKE POWER COMPANY

DATE: September 15, 2003

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

Operating Data Report

Docket No. 50-414
 Date September 15, 2003
 Completed By Roger Williams
 Telephone 704-382-5346

Operating Status

1. Unit Name: Catawba 2
2. Reporting Period: August 1, 2003 - August 31, 2003
3. Licensed Thermal Power (MWt): 3411
4. Nameplate Rating (Gross MWe): 1305 *
5. Design Electrical Rating (Net MWe): 1145
6. Maximum Dependable Capacity (Gross MWe): 1192
7. Maximum Dependable Capacity(Net MWe): 1129
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: *Nameplate Rating (GrossMWe) calculated as 1450.000 MVA * .90 power factor per Page iii, NUREG-0020.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

| | This Month | YTD | Cumulative |
|---|------------|----------|------------|
| 11. Hours in Reporting Period | 744.0 | 5831.0 | 149328.0 |
| 12. Number of Hours Reactor was Critical | 744.0 | 5219.5 | 125024.5 |
| 13. Reactor Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 14. Hours Generator On-Line | 744.0 | 5188.0 | 123568.8 |
| 15. Unit Reserve Shutdown Hours | 0.0 | 0.0 | 0.0 |
| 16. Gross Thermal Energy Generated (MWH) | 2530663 | 17452210 | 406422037 |
| 17. Gross Electrical Energy Generated (MWH) | 898023 | 6249519 | 144895568 |
| 18. Net Electrical Energy Generated (MWH) | 852748 | 5932534 | 136917349 |
| 19. Unit Service Factor | 100.0 | 89.0 | 82.7 |
| 20. Unit Availability Factor | 100.0 | 89.0 | 82.7 |
| 21. Unit Capacity Factor (Using MDC Net) | 101.5 | 90.1 | 81.1 |
| 22. Unit Capacity Factor (Using DER Net) | 100.1 | 88.9 | 80.1 |
| 23. Unit Forced Outage Rate | 0.0 | 0.2 | 6.6 |
| 24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each) | | | |

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

| | Forecast | Achieved |
|----------------------|----------|----------|
| Initial Criticality | _____ | _____ |
| Initial Electricity | _____ | _____ |
| Commercial Operation | _____ | _____ |

UNIT SHUTDOWNS

DOCKET NO. 50-414UNIT NAME: Catawba 2DATE: September 15, 2003COMPLETED BY: Roger WilliamsTELEPHONE: 704-382-5346REPORT MONTH: August, 2003

| No. | Date: | Type F - Forced S - Scheduled | Duration Hours | (1) Reason | (2) Method of Shutdown R/X | Licensed Event Report No. | Cause and Corrective Action to Prevent Recurrence |
|----------|-------|-------------------------------------|-------------------|------------|-------------------------------|---------------------------------|---|
| | | | No | Outages | for the Month | | |
| Summary: | | | | | | | |

(1) Reason

A - Equipment failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory restriction

E - Operator Training/License Examination

F - Administrative

G - Operator Error (Explain)

H - Other (Explain)

(2) Method

1 - Manual

3 - Automatic Trip/Scram

5 - Other (Explain)

2 - Manual Trip/Scram

4 - Continuation

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Catawba Unit 2
2. Scheduled next refueling shutdown: September 2004
3. Scheduled restart following refueling: October 2004

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
(a) in the core: 193
(b) in the spent fuel pool: 917
8. Present licensed fuel pool capacity: 1418
Size of requested or planned increase: ---
9. Projected date of last refueling which can be accommodated by present license capacity:
May 2012

DUKE POWER COMPANY

DATE: September 15, 2003

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

CATAWBA NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

JULY 2003

1. Personnel Exposure -

The total station liquid release for JULY has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for JULY has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.