

3.6 CONTAINMENT SYSTEMS

3.6.1.1 Primary Containmentment

LCO 3.6.1.1 Primary containment shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

-----NOTE-----
Applicable Conditions and Required Actions are not required to be entered for the Inclined Fuel Transfer System (IFTS) penetration for up to 12 hours per cycle when the IFTS blind flange is unbolted.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Primary containment inoperable.	A.1 Restore primary containment to OPERABLE status.	1 hour
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

3.6 CONTAINMENT SYSTEMS

3.6.1.3 Primary Containment Isolation Valves (PCIVs)

LCO 3.6.1.3 Each PCIV shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
MODES 4 and 5 for RHR Shutdown Cooling System suction from
the reactor vessel isolation valves when associated
isolation instrumentation is required to be OPERABLE per
LCO 3.3.6.1, "Primary Containment and Drywell Isolation
Instrumentation," Function 5.c.

-----NOTE-----
The following Applicabilities apply only to secondary
containment bypass leakage isolation valves.

During CORE ALTERATIONS,
During movement of irradiated fuel assemblies in the
primary or secondary containment,
During operations with a potential for draining the reactor
vessel (OPDRVs).

ACTIONS

- NOTES-----
1. Penetration flow paths may be unisolated intermittently under administrative controls.
 2. Separate Condition entry is allowed for each penetration flow path.
 3. Enter applicable Conditions and Required Actions for systems made inoperable by PCIVs.
 4. Enter applicable Conditions and Required Actions of LCO 3.6.1.1, "Primary Containment," when PCIV leakage results in exceeding overall containment leakage rate acceptance criteria in MODES 1, 2, and 3.
 5. Not applicable for the Inclined Fuel Transfer System (IFTS) penetration when the associated primary containment blind flange is removed, provided that the fuel building fuel transfer pool water is maintained \geq el. 753 ft., the steam dryer pool to reactor cavity pool gate is installed with the seal inflated and a backup air supply provided, the total time the flange is open does not exceed 40 days per operating cycle, and the IFTS transfer tube drain valve(s) remain(s) closed, except that the IFTS tube drain valve(s) may be opened under administrative controls.

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.6.1.3.3 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Valves and blind flanges in high radiation areas may be verified by use of administrative means. 2. Not required to be met for PCIVs that are open under administrative controls. <p>-----</p> <p>Verify each primary containment isolation manual valve and blind flange that is located inside primary containment, drywell, or steam tunnel and is required to be closed during accident conditions is closed.</p>	<p>Prior to entering MODE 2 or 3 from MODE 4, if not performed within the previous 92 days</p>

(continued)