

**Mail Envelope Properties (3F6DF4CC.23F : 18 : 20163)**

**Subject:** Staff Comments on Westinghouse's Response to Open Item 14.2-1j  
**Creation Date:** 09/21/2003 2:58PM  
**From:** Joelle Starefos

**Created By:** JLS1@nrc.gov

Recipients	Action	Date & Time
nrc.gov		
owf2_po.OWFN_DO	Delivered	09/21/03 02:58PM
FXT BC (Frank Talbot)	Opened	09/22/03 08:27AM
JPS1 CC (John Segala)	Replied	09/21/03 02:58PM
	Opened	09/22/03 12:40AM
YGH BC (Yi-Hsiung Hsii)	Opened	09/22/03 10:03AM
nrc.gov		
owf4_po.OWFN_DO	Delivered	09/21/03 02:58PM
JXC1 CC (Joseph Colaccino)	Opened	09/22/03 07:22AM
westinghouse.com		
corletmm (Mike Corletti)	Transferred	09/21/03 02:58PM
Post Office	Delivered	Route
owf2_po.OWFN_DO	09/21/03 02:58PM	nrc.gov
owf4_po.OWFN_DO	09/21/03 02:58PM	nrc.gov
		westinghouse.com

Files	Size	Date & Time
Comments OI 14.2-1j.wpd	2666	09/21/03 02:54PM
MESSAGE	1290	09/21/03 02:58PM

**Options**

<b>Auto Delete:</b>	No
<b>Expiration Date:</b>	None
<b>Notify Recipients:</b>	Yes
<b>Priority:</b>	Standard
<b>Reply Requested:</b>	No
<b>Return Notification:</b>	None

<b>Concealed Subject:</b>	No
<b>Security:</b>	Standard

<b>To Be Delivered:</b>	Immediate
<b>Status Tracking:</b>	All Information

**From:** Joelle Starefos  
**To:** Corletti, Mike  
**Date:** 09/21/2003 2:58PM  
**Subject:** Staff Comments on Westinghouse's Response to Open Item 14.2-1j

Mike,

Please see the attached followup comments on Open Item 14.2-1j. If you need any further information or would like to have a discussion with the reviewer, please contact me.

Thanks, Joelle

Joelle L. Starefos  
Project Manager, AP1000  
NRC/NRR/NRLPO  
Mail Stop: OWFN 4D9A  
(301) 415-8488  
jls1@nrc.gov

**CC:** Colaccino, Joseph; Segala, John

**Staff Comments on Westinghouse's Response to Open Item 14.2-1j****OI 14.2-1.j****RE: Test Abstract 14.2.9.1.1 Reactor Coolant System Testing**

The Westinghouse response, letter reference DCP/NRC1615, dated August 26, 2003, provided a table with a cross reference matrix to functions discussed in open item 14.2-1j. Since there is a mismatch between the Reactor Coolant System (RCS) safety-related functions described in the "Purpose" Section and the "General Test Methods and Acceptance Criteria" Section of Test Abstract 14.2.9.1.1, "Reactor Coolant System Testing," please expand the table with the cross reference matrix to include all test functions listed in the test abstract "Purpose" Section.