

November 2, 2003

Mr. John L. Skolds, President
Exelon Nuclear
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3 - WITHDRAWAL OF
AN AMENDMENT REQUEST (TAC NOS. MB7028 AND MB7029)

Dear Mr. Skolds:

By letter dated December 20, 2002, you applied for an amendment to the Dresden Nuclear Power Station, Units 2 and 3, Facility Operating License Nos. DPR-19 and DPR-25. The proposed change would have revised the applicability of facility technical specifications pertaining to Reactor Protection System (RPS) instrumentation, main steam isolation valve closure and turbine condenser vacuum - low functions. The proposed revision was to eliminate the requirement for these functions to be operable while in Mode 2 with reactor pressure greater than or equal to 600 psig, and to delete the associated Required Action such that it aligns with the revised applicability of these functions. Subsequently, by letter dated October 1, 2003, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

/RA/

Maitri Banerjee, Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos.: 50-237 and 50-249

Enclosure: Notice of Withdrawal

cc w/encl: See next page

Mr. John L. Skolds, President
Exelon Nuclear
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

November 2, 2003

SUBJECT: DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3 - WITHDRAWAL OF
AN AMENDMENT REQUEST (TAC NOS. MB7028 AND MB7029)

Dear Mr. Skolds:

By letter dated December 20, 2002, you applied for an amendment to the Dresden Nuclear Power Station, Units 2 and 3, Facility Operating License Nos. DPR-19 and DPR-25. The proposed change would have revised the applicability of facility technical specifications pertaining to Reactor Protection System (RPS) instrumentation, main steam isolation valve closure and turbine condenser vacuum - low functions. The proposed revision was to eliminate the requirement for these functions to be operable while in Mode 2 with reactor pressure greater than or equal to 600 psig, and to delete the associated Required Action such that it aligns with the revised applicability of these functions. Subsequently, by letter dated October 1, 2003, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

/RA/

Maitri Banerjee, Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos.: 50-237 and 50-249

Enclosure: Notice of Withdrawal

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	OGC
PDIII-2	ACRS
WRuland	MRing, RIII
AMendiola	PCoates
MBanerjee	

ADAMS ACCESSION NO.: **ML032790413**

OFFICE	PM:LPD3-2	LA:LPD3-2	OGC/NLO	TL:LPD3-2	SC:LPD3-2
NAME	MBanerjee	PCoates	AFernandez	DPickett	DPickett for, AMendiola
DATE	10/7/2003	10/7/2003	10/15/2003	10/23/2003	10/28/2003

OFFICIAL RECORD COPY

Dresden Nuclear Power Units 2 and 3

cc:

Site Vice President - Dresden Nuclear Power Station
Exelon Generation Company, LLC
6500 N. Dresden Road
Morris, IL 60450-9765

Dresden Nuclear Power Station Plant Manager
Exelon Generation Company, LLC
6500 N. Dresden Road
Morris, IL 60450-9765

Regulatory Assurance Manager - Dresden
Exelon Generation Company, LLC
6500 N. Dresden Road
Morris, IL 60450-9765

U.S. Nuclear Regulatory Commission
Dresden Resident Inspectors Office
6500 N. Dresden Road
Morris, IL 60450-9766

Chairman
Grundy County Board
Administration Building
1320 Union Street
Morris, IL 60450

Regional Administrator
U.S. NRC, Region III
801 Warrenville Road
Lisle, IL 60532-4351

Illinois Emergency Management
Agency
Division of Disaster Assistance &
Preparedness
110 East Adams Street
Springfield, IL 62701-1109

Document Control Desk - Licensing
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Senior Vice President, Nuclear Services
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President - Operations Support
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Chief Operating Officer
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President - Licensing and Regulatory
Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Director - Licensing
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Senior Counsel, Nuclear
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Manager Licensing - Dresden and
Quad Cities
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

UNITED STATES NUCLEAR REGULATORY COMMISSION

DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3

DOCKET NOS. 50-237 AND 50-249

NOTICE OF WITHDRAWAL OF APPLICATION FOR

AMENDMENT TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of Exelon Generation Company, LLC (the licensee) to withdraw its December 20, 2002, application for proposed amendment to Facility Operating License Nos. DPR-19 and DPR-25 for the Dresden Nuclear Power Station, Units 2 and 3, located in Grundy County, Illinois.

The proposed amendment would have revised the applicability of facility technical specifications pertaining to Reactor Protection System (RPS) instrumentation, main steam isolation valve closure and turbine condenser vacuum - low functions, to eliminate the requirement for these functions be operable while in Mode 2 with reactor pressure greater than or equal to 600 psig and delete the associated Required Action to align with the revised applicability of these functions.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on March 18, 2003, (68 FR 12952). However, by letter dated October 1, 2003, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated December 20, 2002, and the licensee's letter dated October 1, 2003, which withdrew the application for license amendment. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems

(ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams/html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, or 301-415-4737 or by email to pdr@nrc.gov.

Dated at Rockville, Maryland, this 2nd day of November 2003.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

Maitri Banerjee, Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation