

3.7 PLANT SYSTEMS

3.7.10 Control Room Emergency Filtration/Pressurization System (CREFS)

LCO 3.7.10 Two CREFS trains shall be OPERABLE

NOTE
The Control Room boundary may be opened intermittently under administrative controls.

APPLICABILITY: MODES 1, 2, 3, 4, 5, and 6,
During movement of irradiated fuel assemblies

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One CREFS train inoperable for reasons other than Condition B.	A.1 Restore CREFS train to OPERABLE status.	7 days
B. Two CREFS Trains inoperable due to inoperable Control Room boundary in MODES 1, 2, 3, and 4.	B.1 Restore control room boundary to OPERABLE status.	24 hours <u>OR</u> 14 days for a one time implementation for each unit of the Turbine Control Digital Modification to be completed during 2RF07 and 1RF10
C. Required Action and associated Completion Time of Condition A or B not met in MODE 1, 2, 3, or 4.	C.1 Be in MODE 3. <u>AND</u> C.2 Be in MODE 5.	6 hours 36 hours

(continued)

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and associated Completion Time of Condition A not met in MODE 5 or 6, or during movement of irradiated fuel assemblies.	D.1 Place OPERABLE CREFS train in emergency recirculation mode.	Immediately
	<u>OR</u>	
	D.2.1 Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u>	
	D.2.2 Suspend movement of irradiated fuel assemblies.	Immediately
E. Two CREFS trains inoperable in MODE 5 or 6, or during movement of irradiated fuel assemblies except for up to 14 days for a one time implementation for each unit of the Turbine Control Digital Modification to be completed during 2RF07 and 1RF10.	E.1 Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u>	
	E.2 Suspend movement of irradiated fuel assemblies.	Immediately
F. Two CREFS trains inoperable in MODE 1, 2, 3, or 4 for reasons other than Condition B.	F.1 Enter LCO 3.0.3.	Immediately