

Document Transmittal Form

TO : NRC C/O PINCKNEY, DAVID
DOCUMENT CONTROL DESK
WASHINGTON, DC 20555

ID : SECG0101

Date : 10/1/03

Please update your controlled set of documents with the following documents:

Document ID	Revision	Status	Quantity	Format	RecNo
PRC SECG-SECG-TOC-BASIS 000	17	A	1	H	177267
PRC SECG-SECT.11.5 (BASIS) 000	2	A	1	H	177305

ALL PAGES of this acknowledgement receipt must be returned to:

**Document Management
PSEG Nuclear
PO Box 236
Hancocks Bridge, NJ 08038**

MC N04

Your signature below verifies that:

(1) the above documents have been filed and superseded documents have been removed and destroyed or clearly marked as obsolete.

(2) the mailing address and copyholder information are correct or corrections have been identified on this transmittal.

☐ Place checkmark here to be removed from controlled distribution

Signature: _____

Date: _____

A045

**SALEM GENERATING STATION
EVENT CLASSIFICATION GUIDE TECHNICAL BASIS
October 1, 2003**

**CHANGE PAGES FOR
REVISION #17**

The Table of Contents forms a general guide to the current revision of each section and attachment of the Salem ECG Technical Basis. The changes that are made in this TOC Revision #17 are shown below.

1. Check that your revision packet is complete.
2. Add the revised documents.
3. Remove and recycle the outdated material listed below.

ADD			REMOVE		
<u>Pages</u>	<u>Description</u>	<u>Rev.</u>	<u>Pages</u>	<u>Description</u>	<u>Rev.</u>
All	TOC	17	All	TOC	16
All	Section 11.5	02	All	Section 11.5	01

**SALEM ECG TECHNICAL BASIS
TABLE OF CONTENTS/SIGNATURE PAGE**

<u>SECTION</u>	<u>TITLE</u>	<u>REV #</u>	<u>PAGES</u>	<u>DATE</u>
T.O.C.	Table of Contents/Signature Page	17	4	10/01/03
i	Introduction and Usage	00	3	01/21/97
ii	Glossary of Acronyms & Abbreviations	00	6	01/21/97
1.0	Fuel Clad Challenge	01	4	12/29/99
2.0	RCS Challenge	01	2	07/24/00
3.0	Fission Product Barriers (Table)			
	3.1 Fuel Clad Barrier	02	20	02/27/03
	3.2 RCS Barrier	02	16	01/16/01
	3.3 Containment Barrier	05	26	01/31/03
4.0	EC Discretion	00	8	01/21/97
5.0	Failure to Trip	03	9	12/18/01
6.0	Radiological Releases/Occurrences			
	6.1 Gaseous Effluent Release	00	42	01/21/97
	6.2 Liquid Effluent Release	00	4	01/21/97
	6.3 In - Plant Radiation Occurrences	00	6	01/21/97
	6.4 Irradiated Fuel Event	00	10	01/21/97
7.0	Electrical Power			
	7.1 Loss of AC Power Capabilities	02	11	01/16/01
	7.2 Loss of DC Power Capabilities	00	8	01/21/97
8.0	System Malfunctions			
	8.1 Loss of Heat Removal Capability	01	10	12/29/99
	8.2 Loss of Overhead Annunciators	02	6	07/24/00
	8.3 Loss of Communications Capability	00	4	01/21/97
	8.4 Control Room Evacuation	01	4	12/18/01
	8.5 Technical Specifications	00	2	01/21/97
9.0	Hazards - Internal/External			
	9.1 Security Threats	02	9	02/01/02
	9.2 Fire	02	6	01/16/01
	9.3 Explosion	02	5	01/16/01
	9.4 Toxic/Flammable Gases	03	12	09/26/02
	9.5 Seismic Event	02	4	09/26/02
	9.6 High Winds	01	5	01/16/01
	9.7 Flooding	02	5	01/16/01
	9.8 Turbine Failure/Vehicle Crash/Missile Impact	02	7	01/16/01
	9.9 River Level	01	4	01/16/01

PSE&G
CONTROL
COPY # SECG0101

**SALEM ECG TECHNICAL BASIS
TABLE OF CONTENTS/SIGNATURE PAGE**

<u>SECTION</u>	<u>TITLE</u>	<u>REV #</u>	<u>PAGES</u>	<u>DATE</u>
----------------	--------------	--------------	--------------	-------------

10.0	Reserved for future use			
------	-------------------------	--	--	--

Licensing is responsible for the Reportable Action Level (Section 11)

11.0	Reportable Action Levels (RALs)			
	11.1 Technical Specifications	01	9	01/23/01
	11.2 Degraded or Unanalyzed Condition	02	4	01/23/01
	11.3 System Actuation	04	7	04/19/02
	11.4 Personnel Safety/Overexposure	01	7	01/23/01
	11.5 Environmental/State Notifications	02	4	10/01/03
	11.6 After-the-Fact	02	1	02/28/02
	11.7 Security/Emergency Response	03	5	02/28/02
	Capabilities			
	11.8 Public Interest	01	3	01/23/01
	11.9 Accidental Criticality/ Special Nuclear Material / Rad Material Shipments - Releases	02	8	01/23/01
	11.10 Voluntary Notifications	01	2	01/23/01

REVISION SUMMARY

Biennial Review Performed: Yes ☐ No ☒

Updated RAL 11.5.2.c in Tech Basis to conform to the approved changes to RAL 11.5.2.c.

SIGNATURE PAGE

Prepared By: William Detwiler 09/03/2003
Date

Section/Attachments Revised: N/A N/A
(List Non Editorial Only - Section/Attachments) Date

Reviewed By: N/A N/A
10CFR50.54q Effectiveness Reviewer Date

Reviewed By: N/A N/A
Department Manager Date

Reviewed By: [Signature] 9/5/03
Manager - Licensing Date
(Reportable Action Level, Section 11)

Reviewed By: [Signature] 9/8/03
EP Manager Date

Reviewed By: NA N/A
Manager - Quality Assurance Date
(If Applicable)

SORC Review and Station Approvals

<u>NA</u>	<u>N/A</u>
Mtg. No. Salem Chairman	Vice President - Nuclear Operations
<u>N/A</u>	<u>N/A</u>
Date	Date

Effective Date of this Revision: 10/01/03
Date

11.0 Reportable Action Levels

11.5 Environmental / State Notifications

REPORTABLE ACTION LEVEL - 11.5.2.a

IC SPILL/DISCHARGE OF ANY NON-RADIOACTIVE HAZARDOUS SUBSTANCE
[10CFR50.72(b)(2)(xi); N.J.A.C. 7:1E]

RAL

Spill/discharge of an industrial chemical or petroleum product outside of a Plant Structure within the Owner Controlled Area (OCA) that results in EITHER one of the following:

- Spill / discharge that has passed through the engineered fill and into the ground water as confirmed by Licensing
- Spill / discharge that CANNOT be cleaned up within **24 hours** and no contact with groundwater is suspected

NOTE:

This event MAY require IMMEDIATE (15 minute) notifications. DO NOT delay implementation of Attachment 16.

MODE - All

BASIS

This RAL addresses the conditions requiring reports IAW PSEG Nuclear's DPCC/DCR Plan. The intent of this RAL is to direct IMMEDIATE implementation of ECG Attachment 16, which will provide further direction on reportability based upon the nature of the Spill/Discharge as well as the expertise of Environmental Licensing personnel concerning requirements.

REFERENCES

10CFR50.72(b)(2)(xi)
N.J.A.C. 7:1E
DPCC/DCR Plan, Part III

PSE&G
CONTROL
COPY # SECG0101

11.0 Reportable Action Levels

11.5 Environmental / State Notifications

REPORTABLE ACTION LEVEL - 11.5.2.b

IC SPILL/DISCHARGE OF ANY NON-RADIOACTIVE HAZARDOUS SUBSTANCE INTO OR UPON THE RIVER [10CFR50.72(b)(2) (vi); N.J.A.C.7:1E]

RAL

EITHER one of the following events occur:

- Observation of a spill/discharge of an industrial chemical or petroleum product from on-site into the Delaware River or into a storm drain
- Observation of an oil slick on the Delaware River from any source.

NOTE:

This event MAY require IMMEDIATE (15 minute) notifications. DO NOT delay implementation of Attachment 16.

MODE - All

BASIS

This RAL addresses the conditions requiring reports IAW PSEG Nuclear's DPCC/DCR Plan. The intent of this RAL is to direct IMMEDIATE implementation of ECG Attachment 16, which will provide further direction on reportability based upon the nature of the Spill/Discharge as well as the expertise of Environmental Licensing personnel concerning requirements.

REFERENCES

10CFR50.72(b)(2)(xi)
N.J.A.C.7:1E
DPCC/DCR Plan, Part III

11.0 Reportable Action Levels

11.5 Environmental / State Notifications

REPORTABLE ACTION LEVEL - 11.5.2.c

IC UNUSUAL OR IMPORTANT ENVIRONMENTAL EVENTS
[ENVIRONMENTAL PROTECTION PLAN SECTION 4.1]

RAL

As judged by the OS/EDO, in concurrence with Environmental Licensing, ANY one of the following events has occurred:

- Unusually large fish kill
- Protected aquatic species impinge on Circulating or Service Water intake screens (e.g., sea turtle, sturgeon) as reported by Site personnel
- Any occurrence of an unusual or important event that indicates or could result in significant environmental impact casually related to plant operation; such as the following:
 - Onsite plant or animal disease outbreaks
 - Mortality or unusual occurrence of any species protected by the Endangered Species Act of 1973
 - Increase in nuisance organisms or conditions
 - Excessive bird impactation
 - Major NJPDES Permit violations
 - Excessive opacity (smoke)

MODE - All

BASIS

This RAL addresses the conditions requiring reports IAW the Environmental Protection Plan. Final determination or reportability will be made by Environmental Licensing as a result of implementing Attachment 15.

REFERENCES

SGS Technical Specifications, ENVIRONMENTAL PROTECTION PLAN

11.0 Reportable Action Levels

11.5 Environmental / State Notifications

REPORTABLE ACTION LEVEL - 11.5.3

IC BOILER OR PRESSURE VESSEL EXPLOSION OR PERSONAL INJURY [N.J.A.C. 5:11-3.11]

RAL

EITHER one of the following events occur:

- Personal injury due to an **occurrence** to a boiler or pressure vessel
- A boiler or pressure vessel **explosion**

MODE - All

BASIS

This RAL addresses the conditions requiring notifications following occurrences to boilers and pressure vessels.

An **occurrence** means any event which reduces the pressure containing capability of, or requires immediate repair to, a boiler or pressure vessel, exclusive of normal wear on the equipment. Per NC.NA-AP.ZZ-0026(Q), this is understood to mean through wall leakage conditions, permanent deformation to a boiler or pressure vessel resulting from transient conditions or service degradation and/or rupture conditions.

An **explosion** is a catastrophic failure of a boiler or pressure vessel that imparts energy of sufficient force to damage or potentially damage permanent plant structures, systems or components.

Immediate notification is required in the event of an **explosion** or a personal injury due to an **occurrence**.

REFERENCES

10CFR50.72(b)(2)(xi)

N.J.A.C.5:11-3.11

Salem ECG 9.3, Explosion

NC.NA-AP.ZZ-0026(Q), NEIL / Jurisdictional Boiler and Machinery Inspection Program