

October 10, 2003

Mr. D. M. Jamil  
Vice President  
Catawba Nuclear Station  
4800 Concord Road  
York, South Carolina 29745

SUBJECT: CATAWBA NUCLEAR STATION, UNITS 1 AND 2 RE: REVISED REQUEST  
FOR ADDITIONAL INFORMATION RESULTING FROM LICENSEE LETTER  
DATED JULY 30, 2003 (TAC NOS. MB7842 AND MB7843)

By letter dated September 17, 2003, we sent you a request for additional information (RAI) that resulted from our review of your letter dated July 30, 2003. On September 29, 2003, we discussed our RAI with you during a conference call and determined that the third question was unclear and should be revised. We agreed to change the third question by deleting the first sentence and deleting the words "as a result" from the second sentence. Enclosed is our revised RAI. We understand that you still intend to provide your response by October 15, 2003. Please contact me at (301) 415-1419 if you have any further questions on this matter.

Sincerely,

**/RA/**

Leonard N. Olshan, Project Manager, Section 1  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosure: As stated

October 10, 2003

Mr. D. M. Jamil  
Vice President  
Catawba Nuclear Station  
4800 Concord Road  
York, South Carolina 29745

SUBJECT: CATAWBA NUCLEAR STATION, UNITS 1 AND 2 RE: REVISED REQUEST  
FOR ADDITIONAL INFORMATION RESULTING FROM LICENSEE LETTER  
DATED JULY 30, 2003 (TAC NOS. MB7842 AND MB7843)

By letter dated September 17, 2003, we sent you a request for additional information (RAI) that resulted from our review of your letter dated July 30, 2003. On September 29, 2003, we discussed our RAI with you during a conference call and determined that the third question was unclear and should be revised. We agreed to change the third question by deleting the first sentence and deleting the words "as a result" from the second sentence. Enclosed is our revised RAI. We understand that you still intend to provide your response by October 15, 2003. Please contact me at (301) 415-1419 if you have any further questions on this matter.

Sincerely,  
*/RA/*

Leonard N. Olshan, Project Manager, Section 1  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosure: As stated

DISTRIBUTION:

PUBLIC	PDII-1 R/F
JNakoski	CHawes
LOlshan	RMartin
OGC	ACRS
RHaag, RII	

ADAMS ACCESSION NUMBER ML032830153

OFFICE	PDII-1/PM	PDII-1/LA	PDII-1/SC
NAME	LOlshan	CHawes	JNakoski
DATE	10/8/03	10/10/03	10/8/03

OFFICIAL RECORD COPY

## REQUEST FOR ADDITIONAL INFORMATION

### CATAWBA UNITS 1 AND 2

#### TECHNICAL SPECIFICATION AMENDMENT - STEAM GENERATORS

The licensee's letter dated July 30, 2003, proposed, in part, the following technical specification wording related to the structural integrity performance criteria:

".... Apart from the above requirements, additional loading conditions associated with the design basis accidents, or combination of accidents in accordance with the design and licensing basis, shall also be evaluated to determine if the associated loads contribute significantly to burst. In the assessment of tube integrity, those loads that significantly affect burst shall be determined and assessed in combination with the loads due to primary to secondary pressure differential using safety factors that are consistent with the licensing basis design criteria."

Following are questions related to this wording:

1. For design basis accident loadings, please discuss whether any loads other than differential pressure loads (i.e., primary membrane (other than from pressure), primary bending, differential thermal) contribute significantly to burst. In addition, please provide a summary of the methodology used to determine whether loads other than differential pressure contribute significantly to burst.
2. For those loads that significantly contribute to burst, if any, please discuss how they were assessed in combination with the loads due to primary to secondary pressure differential.
3. Please provide the safety factors that are consistent with the licensing basis design criteria for loads other than differential pressure. In addition, discuss how these loads (and safety factors) will be combined with the loads due to primary to secondary differential pressure. Include in this discussion, the technical basis for these safety factors and clarify what constitutes the "licensing basis design criteria" for the steam generator tubes.

Enclosure

Catawba Nuclear Station

cc:

Mr. Gary Gilbert  
Regulatory Compliance Manager  
Duke Energy Corporation  
4800 Concord Road  
York, South Carolina 29745

Ms. Lisa F. Vaughn  
Duke Energy Corporation  
Mail Code - PB05E  
422 South Church Street  
P.O. Box 1244  
Charlotte, North Carolina 28201-1244

Anne Cottingham, Esquire  
Winston and Strawn  
1400 L Street, NW  
Washington, DC 20005

North Carolina Municipal Power  
Agency Number 1  
1427 Meadowood Boulevard  
P. O. Box 29513  
Raleigh, North Carolina 27626

County Manager of York County  
York County Courthouse  
York, South Carolina 29745

Piedmont Municipal Power Agency  
121 Village Drive  
Greer, South Carolina 29651

Ms. Karen E. Long  
Assistant Attorney General  
North Carolina Department of Justice  
P. O. Box 629  
Raleigh, North Carolina 27602

NCEM REP Program Manager  
4713 Mail Service Center  
Raleigh, NC 27699-4713

North Carolina Electric Membership  
Corporation  
P. O. Box 27306  
Raleigh, North Carolina 27611

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
4830 Concord Road  
York, South Carolina 29745

Henry Porter, Assistant Director  
Division of Waste Management  
Bureau of Land and Waste Management  
Department of Health and Environmental  
Control  
2600 Bull Street  
Columbia, South Carolina 29201-1708

Mr. C. Jeffrey Thomas  
Manager - Nuclear Regulatory  
Licensing  
Duke Energy Corporation  
526 South Church Street  
Charlotte, North Carolina 28201-1006

Saluda River Electric  
P. O. Box 929  
Laurens, South Carolina 29360

Mr. Peter R. Harden, IV  
VP-Customer Relations and Sales  
Westinghouse Electric Company  
6000 Fairview Road  
12th Floor  
Charlotte, North Carolina 28210

Catawba Nuclear Station

cc:

Mr. T. Richard Puryear  
Owners Group (NCEMC)  
Duke Energy Corporation  
4800 Concord Road  
York, South Carolina 29745

Richard M. Fry, Director  
Division of Radiation Protection  
North Carolina Department of  
Environment, Health, and  
Natural Resources  
3825 Barrett Drive  
Raleigh, North Carolina 27609-7721