

FOR INCLUSION ON TECHNICAL SPECIFICATION WEB PAGE

THE FOLLOWING EXAMPLE OF AN APPLICATION WAS PREPARED BY THE NRC STAFF TO FACILITATE THE USE OF THE CONSOLIDATED LINE ITEM IMPROVEMENT PROCESS (CLIIP). THE MODEL PROVIDES THE EXPECTED LEVEL OF DETAIL AND CONTENT FOR AN APPLICATION TO ADOPT TSTF-421 USING CLIIP. LICENSEES REMAIN RESPONSIBLE FOR ENSURING THAT THEIR ACTUAL APPLICATION FULFILLS THEIR ADMINISTRATIVE REQUIREMENTS AS WELL AS NRC REGULATIONS.

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

SUBJECT: PLANT NAME
DOCKET NO. 50-
APPLICATION FOR TECHNICAL SPECIFICATION IMPROVEMENT TO
EXTEND THE INSPECTION INTERVAL FOR REACTOR COOLANT PUMP
FLYWHEELS USING THE CONSOLIDATED LINE ITEM IMPROVEMENT
PROCESS

Dear Sir or Madam:

Pursuant to 10 CFR 50.90, [license holder] hereby requests an amendment to the Technical Specifications (TS) for [PLANT NAME, UNIT NOS.].

The proposed amendment will extend the reactor coolant pump (RCP) motor flywheel examination frequency from the currently approved 10-year inspection interval, to an interval not to exceed 20 years. The changes are consistent with Industry/Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler, TSTF-421, "Revision to RCP Flywheel Inspection Program (WCAP-15666)." The availability of this TS improvement was announced in the *Federal Register* on [DATE OF NOTICE OF AVAILABILITY] as part of the consolidated line item improvement process (CLIIP).

Attachment 1 provides a description of the proposed change and the requested confirmation of applicability. Attachment 2 provides the existing TS pages marked-up to show the proposed change. Attachment 3 provides revised, clean TS pages.

[LICENSEE] requests approval of the proposed License Amendment by [DATE], with the amendment being implemented [BY DATE OR WITHIN X DAYS].

In accordance with 10 CFR 50.91, a copy of this application, with attachments, is being provided to the designated [STATE] State Official.

I declare under penalty of perjury under the laws of the United States of America that I am authorized by [LICENSEE] to make this request and that the foregoing is true and correct.

If you should have any questions regarding this submittal, please contact [Name/contact information].

Sincerely,

Name, Title

Attachments: 1. Description and Assessment
2. Proposed Technical Specification Changes
3. Revised Technical Specification Pages

cc: NRR Project Manager
Regional Office
Resident Inspector
State Contact

ATTACHMENT 1

Description and Assessment

1.0 INTRODUCTION

The proposed License amendment changes Technical Specification (TS) [5.5.7, "Reactor Coolant Pump Flywheel Inspection Program"]. The changes are consistent with Industry/Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler, TSTF-421, "Revision to RCP Flywheel Inspection Program (WCAP-15666)." The availability of this TS improvement was announced in the *Federal Register* on [DATE OF NOTICE OF AVAILABILITY] as part of the consolidated line item improvement process (CLIIP).

2.0 DESCRIPTION OF PROPOSED AMENDMENT

Consistent with the NRC-approved TSTF-421, the proposed TS change includes the following revision to TS [5.5.7]:

The examination interval for the RCP flywheels is changed from [approximately 10 year intervals coinciding with the Inservice Inspection schedule as required by ASME Section XI] to 20 year intervals.

3.0 BACKGROUND

The background for this application is adequately addressed by the NRC Notice of Availability published on [date] (68 FR xxxxx), NRC Notice for Comment published on June 24, 2003 (68 FR 37590), TSTF-421, WCAP-15666, "Extension of Reactor Coolant Pump Motor Flywheel Examination," and the related NRC safety evaluation (SE) dated May 5, 2003.

4.0 REGULATORY REQUIREMENTS AND GUIDANCE

The applicable regulatory requirements and guidance associated with this application are adequately addressed by the NRC Notice of Availability published on [date] (xx FR xxxxx), NRC Notice for Comment published on June 24, 2003 (68 FR 37590), TSTF-421, WCAP-15666, and the related NRC SE.

5.0 TECHNICAL ANALYSIS

[LICENSEE] has reviewed the model SE published on June 24, 2003 (68 FR 37590), and verified its applicability as part of the CLIIP. This verification included a review of the NRC staff's model SE, as well as the information provided to support TSTF-421 (including WCAP-15666 and the related SE dated May 5, 2003). [LICENSEE] has concluded that the justifications presented in the TSTF proposal and the model SE prepared by the NRC staff are applicable to [PLANT, UNIT NOS.] and justify this amendment for the incorporation of the changes to the [PLANT] TS.

6.0 REGULATORY ANALYSIS

A description of this proposed change and its relationship to applicable regulatory requirements and guidance was provided in the NRC notices related to the CLIIP, TSTF-421, topical report WCAP-15666, and the associated SE.

7.0 NO SIGNIFICANT HAZARDS CONSIDERATION

[LICENSEE] has reviewed the proposed no significant hazards consideration determination published on June 24, 2003 (68 FR 37590) as part of the CLIIP. [LICENSEE] has concluded that the proposed determination presented in the notice is applicable to [PLANT] and the determination is hereby incorporated by reference to satisfy the requirements of 10 CFR 50.91(a).

8.0 ENVIRONMENTAL EVALUATION

[LICENSEE] has reviewed the environmental evaluation included in the model SE published on June 24, 2003 (68 FR 37590) as part of the CLIIP. [LICENSEE] has concluded that the staff's findings presented in that evaluation are applicable to [PLANT] and the evaluation is hereby incorporated by reference for this application.

9.0 PRECEDENT

This application is being made in accordance with the CLIIP. [LICENSEE] is not proposing variations or deviations from the TS changes described in TSTF-421 or the NRC staff's model SE published on June 24, 2003 (68 FR 37590).

10.0 REFERENCES

1. Federal Register Notice: Notice of Availability of Model Application Concerning Technical Specification Improvement Regarding Extension of Reactor Coolant Pump Motor Flywheel Examination for Westinghouse Plants Using the Consolidated Line Item Improvement Process, published [date], (68 FR xxxxxx).
2. Federal Register Notice: Notice of Opportunity to Comment on Model Safety Evaluation on Technical Specification Improvement Regarding Extension of Reactor Coolant Pump Motor Flywheel Examination for Westinghouse Plants Using the Consolidated Line Item Improvement Process, published June 24, 2003 (68 FR 37590).
3. Industry/Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler, TSTF-421, "Revision to RCP Flywheel Inspection Program (WCAP-15666)," Revision 0, November 2001.
4. WCAP-15666, "Extension of Reactor Coolant Pump Motor Flywheel Examination," July 2001.
5. NRC letter dated May 5, 2003, from H. Berkow to R. Bryan (WOG) transmitting Safety Evaluation of WCAP-15666.