



- NOTES:
1. 125 VDC POWER SUPPLY FOR VALVES 2CV-1076-2, 2CV-1025-2, 2CV-795-2, 2CV-712-2, 2CV-712-2 TO BE FROM GREEN BATTERY.
  2. VALVE 2EFW-803 TO REMAIN LOCKED CLOSED UNTIL TECH. SPECS. ARE CHANGED FOR USE OF T-418.
  3. TEMPORARY STARTUP STRAINERS REMOVED DURING NORMAL OPERATION.
  4. OVERLOAD HEATERS WERE REMOVED FROM 2B12K4 IN ORDER TO DISABLE 2CV-8707 IN THE OPEN POSITION.
  5. LOCAL ANNUNCIATION/RETRANSMIT PANEL FOR AUXILIARY FEEDWATER PUMP (2P75) TROUBLE ALARM.

LEGEND	
LINE COLOR	SYSTEM/AMR REPORT
	EMERGENCY FEEDWATER/2P-2005-21
	SERVICE WATER/2P-2005-16
LICENSE RENEWAL BOUNDARY	

**ARKANSAS NUCLEAR ONE**  
RUSSELLVILLE, ARKANSAS

**PIPING & INSTRUMENT DIAGRAM**  
**EMERGENCY FEEDWATER**

DRAWING NO	SHEET	REVISION
LRA-M-2204	4	0

2 BASED ON M-2204 SH 4 REV 631