



- NOTES
1. THE INFORMATION ON THIS DWG. IS BASED ON CE DWG. E-6970-ZIO-160.
 - 2.
 3. BUTT WELD SPENT RESIN LINE CONN. & USE LONG RADIUS PIPE FITTINGS OR BEND PIPE TO SUIT.
 4. THE PURPOSE OF 2F8 2461 IS TO PROVIDE INDICATION OF ANY ACCUMULATION OF WATER IN THE GCH. THIS FB AND THE DRAIN CONNECTION OFF OF LINE ZHBD-24 SHOULD BE LOCATED AS CLOSE AS POSSIBLE TO 2 GCH 30.
 5. DELETE
 6. DELETE
 7. OPEN IF TANK IN SERVICE.

LEGEND			
LINE COLOR	SYSTEM/ANR REPORT		
	CONTAINMENT PENETRATIONS/82-R-2085-86		
	LICENSE RENEWAL BOUNDARY		
ARKANSAS NUCLEAR ONE			
UNIT 2			
RUSSELLVILLE, ARKANSAS			
PIPING & INSTRUMENT DIAGRAM			
BORON MANAGEMENT SYSTEM			
 Entergy	DRAWING NO	SHEET	REVISION
	LRA-M-2214	1	0

OF 08-01-2014 04:11 PM REV 04 1

RED "X" FOR ORIGINAL

2 BASED ON M-2214 SH 1 REV 84 1 RED "X" IF ORIGINAL